



ICI Boiler NO_x & SO₂ Control Cost Estimates

Andrew M. Bodnarik
NH Department of Environmental Services
OTC Committee Meeting
Modeling/Stationary & Area/Mobile Sources
Niagara Falls, NY
September 3, 2009



Outline

- Context - OTC/LADCO State Collaborative Process
 - OTC/LADCO ICI Boiler Workgroup
- Purpose for developing control cost methodology
- Partial List of reference documents used
- Types of NO_x & SO₂ control equipment analyzed
- Uncontrolled NO_x & SO₂ emission ranges
- Controlled NO_x & SO₂ emission ranges
- Comparison of NO_x & SO₂ control cost assumptions
- Summary of ICI boiler NO_x & SO₂ control costs



Context - State Collaborative Process

OTC/LADCO ICI Boiler Workgroup

- **OTC/LADCO December 2005 Meeting**
 - NE and MW Commissioners/Directors met to discuss coordinating control programs to meet current NAAQS, and preparing for new, tighter NAAQS
 - Agreed to explore several control measures, including
 - One consistent environmentally-sensitive formulated gasoline
 - Consistent standards for a range of consumer products
 - **ICI boilers**
- **Regular Conference Calls**
 - On-going discussions over past couple years
 - **Formed ICI Boiler Workgroup with staff from NE and MW states to prepare a recommendation on ICI boilers**
 - Agreed to send letter to EPA



Context - State Collaborative Process OTC/LADCO ICI Boiler Workgroup

- **Letter to EPA (Indiana - November 15, 2007, 16 other states - June 11, 2008)**
 - Asked for a dialogue to address multi-pollutant air quality problems in eastern U.S.
 - Dialogue to include identifying strategies for achieving effective, equitable, and necessary emission reductions (e.g., 3rd phase of reductions for EGUs, and **controls for existing ICI boilers**)
- **OTC/LADCO representatives met with EPA in November 2008**
 - Discussed need for federal action on ICI Boilers including summary of ICI Boiler Workgroup's extensive analysis of technology-based control options and **associated costs**
- **Technical support document being prepared to document OTC/LADCO ICI Boiler Workgroup's analysis**



Purpose for Developing Control Cost Methodology


**To develop improved NO_x & SO₂ control cost estimates for Industrial, Commercial and Institutional (ICI) Boilers using detailed information on direct capital equipment costs, direct installation costs, indirect capital costs and direct & indirect operating costs in a user friendly format
(Excel spreadsheets)**



Background Documents

- Numerous background documents were reviewed (EPA, DOE, OTAG, NACAA*, NESCAUM, LADCO, Federal & State regulations, etc.)
- Control Cost Methodology derived mainly from:
 - “Midwest RPO BART Engineering Analysis” MACTEC, March 30, 2005
 - “ACT Document – NO_x Emissions from ICI Boilers”, EPA 453/R-94-022, March 1994

*NACAA formerly STAPPA & ALAPCO



Types of NO_x Control Equipment Analyzed

- Low NO_x Burners (LNB)
- Low NO_x Burners plus Flue Gas Recirculation (LNB+FGR)
- Low NO_x Burners plus Selective Non-Catalytic Reduction (LNB+SNCR)
- Selective Non-Catalytic Reduction (SNCR)
- Selective Catalytic Reduction (SCR)



Types of SO₂ Control Equipment Analyzed

- **Dry Flue Gas De-Sulfurization (Dry FGD)**

This cost analysis for Dry FGD focused on spray dryer absorption systems which spray lime slurry into an absorption tower where SO₂ is absorbed by the slurry, forming calcium sulfite/calcium sulfate. These dry solids are carried out of the tower and collected by a fabric filter.

- **Wet Flue Gas De-Sulfurization (Wet FGD)**

There are several different versions of Wet FGD systems. The choice of Wet FGD system may be influenced by the sulfur content of the fuel (e.g., limestone forced oxidation systems are generally used when firing high sulfur coal while magnesium enhanced lime systems may be used for low and high sulfur coals). In this cost analysis the Wet FGD system used lime as the base in the scrubbing liquor. Other Wet FGD systems use caustic (NaOH) and limestone.

NOx & SO₂ Control Efficiencies Analyzed

| | NOx | | | | SO ₂ | | |
|-------------------------|-----------------|-----------------|-----------------|--|-------------------|----------------------|---------------------------|
| Option | Gas | Oil | Coal | | Gas | Oil | Coal |
| Combustion Modification | Tune-ups (15%) | Tune-ups (15%) | Tune-ups (15%) | | | | |
| | LNB (50%) | LNB (50%) | LNB (50%) | | | | |
| | LNB + FGR (60%) | LNB + FGR (60%) | LNB + FGR (60%) | | | | |
| | ULNB (75%) | ULNB (75%) | ULNB (75%) | | | | |
| | | | | | | | |
| Fuel Treatment | | | | | COG Desulf. (95%) | Lower S Oil (75-95%) | |
| | | | | | | | |
| Post-Comb. Controls | SNCR (45%) | SNCR (45%) | SNCR (45%) | | | | Dry Sorbent Inject. (40%) |
| | SCR (85%) | SCR (85%) | SCR (85%) | | | | Dry FGD (85-95%) |
| | | | | | | | Wet FGD (85-95%) |



Key Variables That Impact Cost Analyses

- Boiler Type
- Boiler Firing type
- Type of Fuel Combusted
 - (coal, residual oil, distillate oil, natural gas)
- Type of Emission Control
- Uncontrolled Emission Rate
- Controlled Emission Rate
- Capital Cost of Control Equipment
 - (purchased equipment cost)
- Financial costs (e.g., interest rates)
- Unit Capacity Factor (hours/year)
- Flue Gas Flow Rates and Temperatures
- Commodity Prices (e.g., lime, water)



ICI Boiler Uncontrolled NO_x Emission Rates Used in Cost Calculations

- Wall-fired Coal 0.70 lb NO_x/mmBtu
- Residual Oil 0.40 lb NO_x/mmBtu
- Distillate Oil 0.20 lb NO_x/mmBtu
- Natural Gas 0.20 lb NO_x/mmBtu

Actual emission rates will vary based on: NO_x control type, fuel type, boiler type, boiler firing type, age of boiler, current regulatory requirements, etc.



ICI Boiler **Controlled** NO_x Emission Rates Used in Cost Calculations

- Wall-fired Coal 0.11- 0.39 lb NO_x/mmBtu
- Residual Oil 0.0675 - 0.20 lb NO_x/mmBtu
- Distillate Oil 0.03 - 0.11 lb NO_x/mmBtu
- Natural Gas 0.03 – 0.11 lb NO_x/mmBtu

Actual emission rates will vary based on: NO_x control type, fuel type, boiler type, boiler firing type, age of boiler, current regulatory requirements, etc.



ICI Boiler Uncontrolled SO₂ Emission Rates Used in Cost Calculations

- Wall-fired Coal 5.00 lb SO₂/mmBtu

Actual emission rates will vary based on: SO₂ control type, fuel type, boiler type, boiler firing type, age of boiler, current regulatory requirements, etc.



ICI Boiler Controlled SO₂ Emission Rates Used in Cost Calculations

- Wall-fired Coal 0.25 - 0.75 lb SO₂/mmBtu

Actual emission rates will vary based on:
SO₂ control type, fuel type, boiler type,
boiler firing type, age of boiler, current
regulatory requirements, etc.




Comparison of NOx Control Cost Assumptions

■ Direct Capital Costs Comparison

(EPA NOx ACT/MACTEC/OTC-LADCO 2008)

- Instrumentation* (10% / 10% / 10%)
- Sales taxes* (3% / 6% / 6%)
- Freight* (5% / 5% / 5%)

* % of NOx control equipment cost



Comparison of NO_x Control Cost Assumptions (Continued)

- Direct Installation Costs*
Comparison

(EPA NO_x ACT / MACTEC / OTC-LADCO 2008)

(30% / 74% / 40%)

* % of Total Purchased Equipment Cost

- Direct Installation Costs include:

Foundations & supports, handling, electrical, piping, insulation, painting, etc.



Comparison of NO_x Control Cost Assumptions (Continued)

- Indirect Capital Costs* Comparison

(EPA NO_x ACT / MACTEC / OTC-LADCO 2008)

(53%-86%** / 55% / 61%-92%**)

* % of Total Purchased Equipment Cost

** Use higher % for SCR installations

- Indirect Capital Costs include:

Engineering supervision, construction field expenses, construction fees, start-up costs, testing & contingencies, etc.

Comparison of NOx Control Cost Assumptions (Continued)

■ Direct Operating Costs

- Vary with type of boiler and NOx control equipment type


■ Indirect Operating Costs

(EPA NOx ACT / MACTEC / OTC-LADCO 2008)

- Overhead* (60% / 60% / 60%)
- Administrative** (2% / 2% / 2%)
- Property Tax** (1% / 1% / 1%)
- Insurance** (1% / 1% / 1%)

* % of labor & maintenance materials costs

** % of total capital cost



Comparison of NO_x Control Cost Assumptions (Continued)

■ Other Cost Inputs Comparison

(EPA NO_x ACT / MACTEC / OTC-LADCO 2008)

Equipment Service Life (10 yrs / 20 yrs / 15 yrs)

Interest Rate (10% / 7% / 10%)

Capital Recovery Factor (0.1627 / 0.0944 / 0.1133)

ICI Boiler NOx Control Cost Estimates (\$/ton NOx removed)

- Control Technology – Low NOx Burners
- Fuel Type – Natural Gas
- 50% NOx Reduction

(from 0.20 lb. NOx/mmBtu to 0.10 lb. NOx/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton NOx removed)</u> | | |
|--------------------|------------------------------|---------------|-------------|
| | <u>Capital Cost Scenario</u> | | |
| | <u>Low</u> | <u>Medium</u> | <u>High</u> |
| 50 | \$10,900 | \$14,700 | \$43,600 |
| 100 | \$5,460 | \$7,350 | \$21,800 |
| 250 | \$2,190 | \$2,940 | \$8,720 |
| 750 | \$728 | \$980 | \$2,910 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler NOx Control Cost Estimates (\$/ton NOx removed)

- Control Technology – Low NOx Burners
- Fuel Type – Distillate Oil
- 50% NOx Reduction

(from 0.20 lb. NOx/mmBtu to 0.10 lb. NOx/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton NOx removed)</u> | | |
|--------------------|------------------------------|---------------|-------------|
| | <u>Capital Cost Scenario</u> | | |
| | <u>Low</u> | <u>Medium</u> | <u>High</u> |
| 50 | \$10,900 | \$14,700 | \$43,600 |
| 100 | \$5,460 | \$7,350 | \$21,800 |
| 250 | \$2,190 | \$2,940 | \$8,720 |
| 750 | \$728 | \$980 | \$2,910 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler NOx Control Cost Estimates (\$/ton NOx removed)

- Control Technology – Low NOx Burners
- Fuel Type – Residual Oil
- 50% NOx Reduction

(from 0.40 lb. NOx/mmBtu to 0.20 lb. NOx/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton NOx removed)</u> | | |
|--------------------|------------------------------|---------------|-------------|
| | <u>Capital Cost Scenario</u> | | |
| | <u>Low</u> | <u>Medium</u> | <u>High</u> |
| 50 | \$5,460 | \$7,352 | \$21,800 |
| 100 | \$2,730 | \$3,680 | \$10,900 |
| 250 | \$1,090 | \$1,470 | \$4,360 |
| 750 | \$364 | \$490 | \$1,450 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler NOx Control Cost Estimates (\$/ton NOx removed)

- Control Technology – Low NOx Burners
- Fuel Type – Wall-fired Coal
- 50% NOx Reduction

(from 0.70 lb. NOx/mmBtu to 0.35 lb. NOx/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton NOx removed)</u> | | |
|--------------------|------------------------------|---------------|-------------|
| | <u>Capital Cost Scenario</u> | | |
| | <u>Low</u> | <u>Medium</u> | <u>High</u> |
| 50 | \$3,120 | \$4,200 | \$12,460 |
| 100 | \$1,560 | \$2,100 | \$6,230 |
| 250 | \$624 | \$840 | \$2,490 |
| 750 | \$208 | \$280 | \$831 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler NOx Control Cost Estimates (\$/ton NOx removed)

- Control Technology – LNB plus FGR
- Fuel Type – Residual Oil
- 60% NOx Reduction

(from 0.40 lb. NOx/mmBtu to 0.16 lb. NOx/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton NOx removed)</u> | |
|--------------------|------------------------------|-------------|
| | <u>Capital Cost Scenario</u> | |
| | <u>Low</u> | <u>High</u> |
| 50 | \$13,200 | \$26,800 |
| 100 | \$6,600 | \$13,400 |
| 250 | \$2,640 | \$5,360 |
| 750 | \$880 | \$1,790 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler NOx Control Cost Estimates (\$/ton NOx removed)

- Control Technology – LNB plus SNCR
- Fuel Type – Residual Oil
- 65% NOx Reduction

(from 0.40 lb. NOx/mmBtu to 0.14 lb. NOx/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton NOx removed)</u> | |
|--------------------|-----------------------------|-------------|
| | Capital Cost Scenario | |
| | <u>Low</u> | <u>High</u> |
| 50 | \$13,770 | \$28,200 |
| 100 | \$7,370 | \$14,600 |
| 250 | \$3,520 | \$6,410 |
| 750 | \$1,810 | \$2,770 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler NOx Control Cost Estimates (\$/ton NOx removed)

- Control Technology – SNCR
- Fuel Type – Residual Oil
- 50% NOx Reduction

(from 0.40 lb. NOx/mmBtu to 0.20 lb. NOx/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton NOx removed)</u> | |
|--------------------|------------------------------|-------------|
| | <u>Capital Cost Scenario</u> | |
| | <u>Low</u> | <u>High</u> |
| 50 | \$10,550 | \$14,840 |
| 100 | \$5,900 | \$8,040 |
| 250 | \$3,110 | \$3,970 |
| 750 | \$1,870 | \$2,150 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler NOx Control Cost Estimates (\$/ton NOx removed)

- Control Technology – SNCR
- Fuel Type – Wall-fired Coal
- 45% NOx Reduction

(from 0.70 lb. NOx/mmBtu to 0.39 lb. NOx/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton NOx removed)</u> | |
|--------------------|-----------------------------|-------------|
| | Capital Cost Scenario | |
| | <u>Low</u> | <u>High</u> |
| 50 | \$7,210 | \$9,930 |
| 100 | \$4,260 | \$5,620 |
| 250 | \$2,480 | \$3,030 |
| 750 | \$1,690 | \$1,880 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler NOx Control Cost Estimates (\$/ton NOx removed)

- Control Technology – SCR
- Fuel Type – Residual Oil
- 85% NOx Reduction

(from 0.40 lb. NOx/mmBtu to 0.0675 lb. NOx/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton NOx removed)</u> | |
|--------------------|------------------------------|-------------|
| | <u>Capital Cost Scenario</u> | |
| | <u>Low</u> | <u>High</u> |
| 50 | \$11,220 | \$39,800 |
| 100 | \$5,840 | \$20,100 |
| 250 | \$2,620 | \$8,330 |
| 750 | \$1,180 | \$3,080 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler NOx Control Cost Estimates (\$/ton NOx removed)

- Control Technology – SCR
- Fuel Type – Wall-fired Coal
- 85% NOx Reduction

(from 0.70 lb. NOx/mmBtu to 0.11 lb. NOx/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton NOx removed)</u> | |
|--------------------|------------------------------|-------------|
| | <u>Capital Cost Scenario</u> | |
| | <u>Low</u> | <u>High</u> |
| 50 | \$6,500 | \$22,840 |
| 100 | \$3,430 | \$11,600 |
| 250 | \$1,590 | \$4,860 |
| 750 | \$770 | \$1,860 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler SO₂ Control Cost Estimates (\$/ton SO₂ removed)

- Control Technology – Dry FGD
- Fuel Type – Wall-fired Coal

85% SO₂ Reduction
(from 5.00 lb. to 0.75 lb. SO₂/mmBtu)

95% SO₂ Reduction
(from 5.00 lb. to 0.25 lb. SO₂/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton SO₂ removed)</u> | | <u>(\$/ton SO₂ removed)</u> | |
|--------------------|--|-------------|--|-------------|
| | Capital Cost | | Capital Cost | |
| | <u>Low</u> | <u>High</u> | <u>Low</u> | <u>High</u> |
| 100 | \$1,780 | \$7,690 | \$1,590 | \$6,880 |
| 250 | \$1,650 | \$4,010 | \$1,480 | \$3,590 |
| 750 | \$1,590 | \$2,380 | \$1,420 | \$2,130 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year

ICI Boiler SO₂ Control Cost Estimates (\$/ton SO₂ removed)

- Control Technology – **Wet FGD**
- Fuel Type – **Wall-fired Coal**

85% SO₂ Reduction
(from 5.00 lb. to 0.75 lb. SO₂/mmBtu)

95% SO₂ Reduction
(from 5.00 lb. to 0.25 lb. SO₂/mmBtu)

| <u>Boiler Size</u> | <u>(\$/ton SO₂ removed)</u> | |
|--------------------|--|-------------|
| | <u>Capital Cost</u> | |
| | <u>Low</u> | <u>High</u> |
| 100 | \$1,840 | \$7,510 |
| 250 | \$1,570 | \$3,830 |
| 750 | \$1,440 | \$2,220 |


| | <u>(\$/ton SO₂ removed)</u> | |
|--|--|-------------|
| | <u>Capital Cost</u> | |
| | <u>Low</u> | <u>High</u> |
| | \$1,650 | \$6,720 |
| | \$1,400 | \$3,430 |
| | \$1,290 | \$1,970 |

All costs shown are in 2008\$ for a 66% capacity factor at 8,760 hours/year



Summary

- Methodology contains sufficient level of detail to develop improved NO_x and SO₂ control cost estimates
- Excel format is user friendly and allows flexibility for user to input case specific data
- Excel format allows user to update data as newer data becomes available



Bonus Material

San Joaquin Valley APCD

ICI Boiler NOx Control Cost Estimates

Final Draft Staff Report (9/18/08)

- Control Technology – Ultra Low NOx Burners
- Fuel Type – Natural Gas
- 69% NOx Reduction
[from 30 ppmv (0.036 lb. NOx/mmBtu) to 9 ppmv (0.011 lb. NOx/mmBtu)]

| <u>Boiler Size</u> | <u>Capital Cost (\$)</u> | <u>(\$/ton NOx removed)</u> | |
|--------------------|--------------------------|-----------------------------|------------|
| | | <u>Capacity Factor</u> | |
| | | <u>50%</u> | <u>75%</u> |
| 44 | \$114,172 | \$13,931 | \$9,289 |
| 68 | \$127,200 | \$11,748 | \$7,833 |
| 92 | \$151,766 | \$10,754 | \$7,170 |
| 115 | \$179,672 | \$10,556 | \$7,037 |
| 130 | \$194,560 | \$10,234 | \$6,823 |
| 150 | \$214,411 | \$9,914 | \$6,609 |

Comparison of NO_x and SO₂ Control Cost Estimates for ICI Boilers

Literature Values
MACTEC 2008 Results
Modified CUECost Results
January, 2009

Data Sources of NO_x & SO₂ Control Cost Estimates

- **Literature** - Refers to data taken from NESCAUM report “Applicability and Feasibility of NO_x, SO₂ and PM Emission Control Technologies for ICI Boilers”, November 2008, Executive Summary, Table ES-1.
- **MACTEC 2008** - Refers to data derived using the MACTEC methodology with corrections and assumptions developed by the OTC/LADCO ICI Boiler Workgroup.
- **Modified CUECost** - Refers to the data taken from NESCAUM report “Applicability and Feasibility of NO_x, SO₂ and PM Emission Control Technologies for ICI Boilers”, November 2008, Chapter 5, Tables 5-4 and 5-5.

Cost Estimates for **NO_x** Control Technology Options (\$/ton **NO_x** Removed)

| Control Technology | Fuel Type | Cost Method | Boiler Size | |
|---|----------------|-------------------------------|--------------------|-------------------|
| | | | 100 MMBTU/hr | 250 MMBTU/hr |
| Low NO _x Burners - Gas | Gas | Literature ¹ | \$750 - \$7,500 | |
| | | MACTEC 2008 ² | \$5,460 - \$21,800 | \$2,190 - \$8,720 |
| | | Modified CUECost ³ | \$5,715 | \$4,151 |
| Low NO _x Burners - Dist. Oil | Distillate Oil | Literature ¹ | \$750 - \$7,500 | |
| | | MACTEC 2008 ² | \$5,460 - \$21,800 | \$2,190 - \$8,720 |
| Low NO _x Burners - Res. Oil | Residual Oil | Literature ¹ | \$750 - \$7,500 | |
| | | MACTEC 2008 ² | \$2,730 - \$10,900 | \$1,090 - \$4,360 |
| | | Modified CUECost ³ | \$4,559 | \$3,305 |
| Low NO _x Burners - Coal | Coal | Literature ¹ | \$750 - \$7,500 | |
| | | MACTEC 2008 ² | \$1,560 - \$6,230 | \$624 - \$2,490 |
| | | Modified CUECost ³ | \$3,155 | \$2,290 |

1. Literature values are in 2006\$.

2. MACTEC 2008 values are in 2008\$ for a 66% capacity factor at 8,760 hours/year.

3. Modified CUECost values are in 2006\$ for a 66% capacity factor at 8,760 hours/year.

Cost Estimates for **NO_x** Control Technology Options (\$/ton **NO_x** Removed)

| Control Technology | Fuel Type | Cost Method | Boiler Size | |
|--------------------------|-----------|-------------------------------|--------------------|-------------------|
| | | | 100 MMBTU/hr | 250 MMBTU/hr |
| SNCR - Coal (Wall-fired) | Coal | Literature ¹ | \$1,300 - \$3,700 | |
| | | MACTEC 2008 ² | \$4,260 - \$5,620 | \$2,480 - \$3,030 |
| | | Modified CUECost ³ | \$4,817 | \$2,422 |
| SCR - Coal (Wall-Fired) | Coal | Literature ¹ | \$2,000 - \$14,400 | |
| | | MACTEC 2008 ² | \$3,430 - \$11,600 | \$1,590 - \$4,860 |
| | | Modified CUECost ³ | \$6,668 | \$4,763 |

1. Literature values are in 2006\$.

2. MACTEC 2008 values are in 2008\$ for a 66% capacity factor at 8,760 hours/year.

3. Modified CUECost values are in 2006\$ for a 66% capacity factor at 8,760 hours/year.

Cost Estimates for **SO₂** Control Technology Options (\$/ton **SO₂** Removed)

| Control Technology | Fuel Type | Cost Method | Boiler Size | |
|-----------------------------|----------------|---------------------------------|-------------------|-------------------|
| | | | 100 MMBTU/hr | 250 MMBTU/hr |
| Fuel Switch 0.3%S to 0.05%S | Distillate Oil | Price Differential ¹ | \$1,200 - \$2,000 | |
| Fuel Switch 1.0%S to 0.5% S | Residual Oil | Price Differential ¹ | \$1,900 - \$3,800 | |
| Dry FGD – Coal | Coal | Literature ² | \$1,600 - \$5,200 | |
| | | MACTEC 2008 ³ | \$1,590 - \$7,690 | \$1,480 - \$4,010 |
| | | Modified CUECost ⁴ | \$7,909 | \$3,694 |
| Wet FGD (Wall-Fired) | Coal | Literature ² | \$1,900 - \$5,200 | |
| | | MACTEC 2008 ³ | \$1,650 - \$7,510 | \$1,400 - \$3,830 |
| | | Modified CUECost ⁴ | \$9,547 | \$4,427 |

1. Price Differential values are in 2008\$ for a 66% capacity factor at 8,760 hours/year.
Price differential between 0.3%S and 0.05%S distillate oil ranged from 2.1 to 3.5 cents per gallon
Price differential between 1.0%S and 0.5%S residual oil ranged from 7.5 to 15.0 cents per gallon
2. Literature values are in 2006\$.
3. MACTEC 2008 values are in 2008\$ for a 66% capacity factor at 8,760 hours/year.
4. Modified CUECost values are in 2006\$ for a 66% capacity factor at 8,760 hours/year.

Additional Information

Recommended National ICI Boiler NO_x & SO₂ Emission Limits and Control Cost Estimates

Work in Progress
4th DRAFT (1/15/09)

Andrew M. Bodnarik

NH Department of Environmental Services

January, 2009

Recommended National ICI Boiler **NO_x** Emission Limits

- **Gaseous Fuels** (natural gas, refinery gas, blast furnace gas, coke oven gas)
 - **Phase I (2012 - 2015)**
 - **<50 - 100 MMBtu/hr - Combustion Tuning**
 - **> 100 MMBtu/hr - 0.10 lb NO_x/MMBtu or
50% NO_x reduction**
 - **Phase II (2015 - 2018)**
 - **< 50 MMBtu/hr - 0.05 - 0.10 lb NO_x/MMBtu or
50% NO_x reduction**
 - **50 - > 100 MMBtu/hr - 0.05 - 0.10 lb NO_x/MMBtu or
60% NO_x reduction**

Recommended National ICI Boiler **NO_x** Emission Limits (Continued)

- **Distillate Oil** (#2 fuel oil)
 - **Phase I (2012 - 2015)**
 - **<50 - 100 MMBtu/hr - Combustion Tuning**
 - **> 100 MMBtu/hr - 0.10 lb NO_x/MMBtu or
50% NO_x reduction**
 - **Phase II (2015 - 2018)**
 - **< 50 MMBtu/hr - 0.08 - 0.10 lb NO_x/MMBtu or
50% NO_x reduction**
 - **50 - > 100 MMBtu/hr - 0.08 - 0.10 lb NO_x/MMBtu or
60% NO_x reduction**

Recommended National ICI Boiler **NO_x** Emission Limits (Continued)

- **Residual Oil** (#6 fuel oil)
 - Phase I (2012 - 2015)
 - <50 - 100 MMBtu/hr - Combustion Tuning
 - > 100 MMBtu/hr - 0.20 lb NO_x/MMBtu or
60% NO_x reduction
 - Phase II (2015 - 2018)
 - < 50 MMBtu/hr - 0.20 lb NO_x/MMBtu or
50% NO_x reduction
 - 50 - 100 MMBtu/hr - 0.20 lb NO_x/MMBtu or
60% NO_x reduction
 - > 100 MMBtu/hr - 0.20 lb NO_x/MMBtu or
70% NO_x reduction

Recommended National ICI Boiler **NO_x** Emission Limits (Continued)

- **Coal (Wall-fired) > 100 MMBtu/hr**
 - Phase I (2012 - 2015) - 0.30 lb NO_x/MMBtu
 - Phase II (2015 - 2018) - 0.10 - 0.14 lb NO_x/MMBtu
- **Coal (Tangential) > 100 MMBtu/hr**
 - Phase I (2012 - 2015) - 0.30 lb NO_x/MMBtu
 - Phase II (2015 - 2018) - 0.10 - 0.12 lb NO_x/MMBtu
- **Coal (Cyclone) > 100 MMBtu/hr**
 - Phase I & Phase II - 0.19 lb NO_x/MMBtu

Recommended National ICI Boiler **NO_x** Emission Limits (Continued)

- **Coal (Stoker)**

Phase I (2012 - 2015)

50 - 100 MMBtu/hr - Combustion Tuning

>100 MMBtu/hr - 0.30 lb NO_x/MMBtu

Phase II (2015 - 2018)

50 - 100 MMBtu/hr - 0.30 lb NO_x/MMBtu

>100 MMBtu/hr - 0.22 lb NO_x/MMBtu

- **Coal (Fluidized Bed)**

Phase I (2012 - 2015)

50 - 100 MMBtu/hr - Combustion Tuning

>100 MMBtu/hr - 0.15 lb NO_x/MMBtu

Phase II (2015 - 2018)

50 - >100 MMBtu/hr - 0.08 lb NO_x/MMBtu

Recommended National ICI Boiler SO₂ Emission Limits

- **Coke Oven Gas - > 100 MMBtu/hr**
 - Phase I (2012-2014) & Phase II (2014-2018) remove 95% of Sulfur from coke oven gas
- **#2 Distillate Oil - < 50 - >250 MMBtu/hr**
 - Phase I (2012-2014) - 500 ppm Sulfur or 0.05 lb SO₂/MMBtu
 - Phase II Northeast Inner Zone States* (2016) - 15 ppm Sulfur
 - Phase II Elsewhere (2018) - 15 ppm Sulfur
- **#6 Residual Oil - < 50 - >250 MMBtu/hr**
 - Phase II Northeast Inner Zone States* (2012) - 0.3-0.5% Sulfur
 - Phase II Elsewhere (2018) - 0.5% Sulfur

* The Northeast Inner Zone States are the same as specified in the MANE-VU “low sulfur oil strategy” Statement (6/20/07) namely NJ, NY, DE & PA.

Recommended National ICI Boiler SO₂ Emission Limits (Continued)

- **Coal (and other solid fuels)**

- **Phase I (2012-2015)**

- 50 - 100 MMBtu/hr - 2.0 lb SO₂/MMBtu or 30% reduction*
- 100 - 250 MMBtu/hr - 1.2 lb SO₂/MMBtu or 85% reduction*
- > 250 MMBtu/hr - 0.25 lb SO₂/MMBtu or 85% reduction*

- **Phase II (2012-2015)**

- 50 - 100 MMBtu/hr - 2.0 lb SO₂/MMBtu or 30% reduction*
- 100 - 250 MMBtu/hr - 0.25 lb SO₂/MMBtu or 85% reduction*
- > 250 MMBtu/hr - 0.25 lb SO₂/MMBtu or 85% reduction*

* % reduction is from uncontrolled SO₂ emissions in base year 2002

Recommended National ICI Boiler **NOx** Emission Limits

(% values are %NOx reductions. All other values are lb. NOx/MMBTU.)

| Fuel Type | | Boiler Size (MMBTU/Hour) | | |
|--|----------|--------------------------|--------------------|--------------------|
| | | < 50 | 50-100 | > 100 |
| Gaseous Fuels (natural gas, refinery gas, blast furnace gas, coke oven gas) | Phase I | Comb. Tuning | Comb. Tuning | 0.10 or 50% |
| | Phase II | 0.05 - 0.10 or 50% | 0.05 - 0.10 or 60% | 0.05 - 0.10 or 60% |
| Distillate Oil (#1,#2) | Phase I | Comb. Tuning | Comb. Tuning | 0.10 or 50% |
| | Phase II | 0.08 - 0.10 or 50% | 0.08 - 0.10 or 60% | 0.08 - 0.10 or 60% |
| Residual Oil (#4,#5,#6) | Phase I | Comb. Tuning | Comb. Tuning | 0.20 or 60% |
| | Phase II | 0.20 or 50% | 0.20 or 60% | 0.20 or 70% |
| Coal - Wall | Phase I | | | 0.30 |
| | Phase II | | | 0.10 - 0.14 |
| Coal - Tangential | Phase I | | | 0.30 |
| | Phase II | | | 0.10 - 0.12 |
| Coal - Cyclone | Phase I | | | 0.19 |
| | Phase II | | | 0.19 |
| Coal - Stoker | Phase I | | Comb. Tuning | 0.30 |
| | Phase II | | 0.30 | 0.22 |
| Coal - FBC | Phase I | | Comb. Tuning | 0.15 |
| | Phase II | | 0.08 | 0.08 |
| Wood and Non-Fossil Solid Fuel | Phase I | | Comb. Tuning | 0.30 |
| | Phase II | | 0.30 | 0.22 |

Recommended National ICI Boiler **SO₂** Emission Limits

| Fuel Type | | Boiler Size (MMBtu/Hour) | | | |
|-------------------------------|---|---|--|--|--|
| | | < 50 | 50-100 | 100-250 | > 250 |
| Gaseous Fuels (coke oven gas) | Phase I | | | Treated COG with 95% S compounds removed | Treated COG with 95% S compounds removed |
| | Phase I | | | Treated COG with 95% S compounds removed | Treated COG with 95% S compounds removed |
| Distillate Oil (#1, #2) | Phase I | 0.05% S (500ppm), or 0.05 lb/MMBTU | 0.05% S (500ppm), or 0.05 lb/MMBTU | 0.05% S (500ppm), or 0.05 lb/MMBTU | 0.05% S (500ppm), or 0.05 lb/MMBTU |
| | Phase II Northeast States Inner Zone | Further reduce Sulfur content to 15ppm by 2016 | Further reduce Sulfur content to 15ppm by 2016 | Further reduce Sulfur content to 15ppm by 2016 | Further reduce Sulfur content to 15ppm by 2016 |
| | Phase II Elsewhere | Further reduce Sulfur content to 15ppm by 2018 | Further reduce Sulfur content to 15ppm by 2018 | Further reduce Sulfur content to 15ppm by 2018 | Further reduce Sulfur content to 15ppm by 2018 |
| Residual Oil (#4, #5, #6) | Phase I | 0.5% S (or 0.54 lb/MMBTU) | 0.5% S (or 0.54 lb/MMBTU) | 0.5% S (or 0.54 lb/MMBTU) | 0.5% S (or 0.54 lb/MMBTU) |
| | Phase II Northeast States Inner Zone | #4 Fuel Oil 0.25% S no later than 2012 | #4 Fuel Oil 0.25% S no later than 2012 | #4 Fuel Oil 0.25% S no later than 2012 | #4 Fuel Oil 0.25% S no later than 2012 |
| | | #6 Fuel Oil 0.3-0.5% no later than 2012 | #6 Fuel Oil 0.3-0.5% S no later than 2012 | #6 Fuel Oil 0.3-0.5% S no later than 2012 | #6 Fuel Oil 0.3-0.5% S no later than 2012 |
| | Phase II Elsewhere | #4 Fuel Oil 0.25-0.5% S no later than 2018 | #4 Fuel Oil 0.25-0.5% S no later than 2018 | #4 Fuel Oil 0.25-0.5% S no later than 2018 | #4 Fuel Oil 0.25-0.5% S no later than 2018 |
| | | #6 Fuel Oil 0.5% S no later than 2018 | #6 Fuel Oil 0.5% S no later than 2018 | #6 Fuel Oil 0.5% S no later than 2018 | #6 Fuel Oil 0.5% S no later than 2018 |
| Coal (and other solid fuels) | Phase I | | 2.0 lb/MMBtu or 30% reduction* | 1.2 lb/MMBtu or 85% reduction* | 0.25 lb/MMBtu or 85% reduction* |
| | Phase II | | 2.0 lb/MMBtu or 30% reduction* | 0.25 lb/MMBTU or 85% reduction* | 0.25 lb/MMBTU or 85% reduction* |
| | | * = % reduction based on uncontrolled emissions in base year (2002) | | | |