

Municipal Waste Combustor Workgroup Report

Prepared by the Ozone Transport Commission Stationary and Area Sources Committee

June 2021



Contents

Introduction	4
Background	4
Method	4
Developing a state-by-state MWC Inventory	4
Developing an Emissions Inventory for the OTR MWCs	5
Conducting a Literature Review to Identify Additional NOx Control Technologies.....	6
Trinity Consultants Studies	6
Babcock Power Environmental	6
Other Resources.....	6
Small MWCs	7
Estimating Tons per Year of NOx that Could Be Reduced with Further Controls.....	7
Researching the Potential Costs of Further MWC NOx Controls.....	9
Findings	10
OTR MWC Inventory of Units and NOx Emissions	10
Technologies to Reduce NOx from MWCs in the OTR.....	11
Babcock Power Environmental Study	12
Implementation Examples of LN™ and ASNCR	14
Potential NOx Reductions Resulting from Installing Additional Control Technologies	16
Control Costs.....	17
Cost Estimate for a 24-Hour NOx Limit of 110 ppmvd using LN™.....	18
Non-OTR MWCs	21
Policy Implications	22
Additional Research	22
Conclusions	22
Appendix A: OTR Large MWC Actual and Proposed Emissions	23
Appendix B: OTR Large MWC Characteristics	31
Appendix C: OTR Small MWCs	38
Appendix D: Non-OTR MWC	39
Appendix E: Conversion of NOx Concentration to Mass	43
Appendix F: MWC Technology Descriptions.....	45
Appendix G: Method for Estimating Costs for Urea Consumption.....	59

Acronyms

ASNCR	Advanced selective non-catalytic reduction
BACT	Best available control technology
CEM	Continuous emission monitor
CFD	Computational fluid dynamics
CFR	Code of federal regulations
EGU	Electric generating units
EIA	Energy Information Administration
EPA	U.S. Environmental Protection Agency
FGR	Flue gas recirculation
LN™	Low NOx technology
MMbtu	Million British thermal units
MWC	Municipal waste combustors
NOx	Nitrogen oxides
NSR	Normalized stoichiometric ratio
OTC	Ozone Transport Commission
OTR	Ozone Transport Region
PM	Particulate matter
ppm	Parts per million
ppmvd	Parts per million dry volume
RACT	Reasonably available control technology
RDF	Refuse derived fuel
SAS	Stationary and Area Sources Committee
SCR	Selective catalytic reduction
SNCR	Selective non-catalytic reduction
SOx	Sulfur oxides
VLN™	Very low NOx technology

Introduction

This report summarizes results from a municipal waste combustor (MWC) pilot project conducted by the Ozone Transport Commission (OTC) Stationary and Area Sources (SAS) Committee. The report provides an estimate of oxides of nitrogen (NO_x) emissions from Ozone Transport Region (OTR) MWCs, identifies opportunities for additional NO_x reductions from the units, and provides example costs for installing additional NO_x controls on OTR MWCs. The report has five sections, including background information, an overview of methods used in the pilot study, findings, policy implications, and conclusions. There are seven appendices to the report, three of which detail emissions and operating characteristics of the approximately 100 MWCs in the OTR, one that provides information on MWCs outside of the OTR, two that provide calculations for converting NO_x concentrations to mass emissions and costs for urea use, and one which describes MWC emission reduction technologies.

Background

During the development of the 2020 Stationary and Area Sources Committee Charge, SAS Committee members identified a number of sectors, including MWCs, small electric generating units, and others, as significant sources of NO_x emissions in the OTR. In the 2020 Charge, the SAS Committee prioritized MWCs for a pilot project as the first sector for evaluation. The pilot was intended to provide a template for evaluation of other sectors in the region. The SAS Committee formed an MWC workgroup to conduct an evaluation of MWCs in the region and the results of that effort are described in this report.

In 2018, MWCs emitted approximately 22,000 tons of NO_x in the OTR. Nine states in the OTR have MWCs and have established Reasonably Available Control Technology (RACT) regulatory or permit limits for the MWC NO_x emissions. These states are: Connecticut, Massachusetts, Maryland, Maine, New Hampshire, New Jersey, New York, Pennsylvania, and Virginia. Some OTC states have initiated a process to update NO_x RACT for MWCs and this potentially provides an opportunity to strengthen emissions limits.

Method

The pilot study was directed by the members of the SAS MWC workgroup. The sub-sections that follow in this section describe each basic step of the analysis method. In brief, these steps consisted of:

- 1) Developing a state-by-state OTR MWC unit inventory;
- 2) Estimating tons of NO_x emitted annually from each MWC;
- 3) Conducting a literature review to identify additional control technologies;
- 4) Estimating tons per year of NO_x that could be reduced with further controls; and
- 5) Researching and estimating the potential costs of further MWC NO_x controls.

Developing a state-by-state MWC Inventory

In this step, MWC workgroup members compiled information in an Excel spreadsheet for each of the MWCs in their states. The information included the MWC unit ID, plant name, location, type of MWC, capacity (in tons of refuse processed per day), permit or RACT limits, existing control technology, and other information. In addition, using the federal definition, the workgroup segmented MWCs into “large” or “small” MWCs. A large unit has the capacity to process greater than 250 tons per day of

refuse, and a small unit has the capacity to process no more than 250 tons of refuse per day. Small units referred to in this report includes a “very small” category of MWCs defined in 40 CFR Part 60 as units that process less than 35 tons of refuse per day. MWCs were also categorized by technology type based on 40 CFR part 60 classifications.¹ The purpose of categorizing the MWCs was to identify characteristics of the MWCs that would either lend themselves to further emission controls or preclude further emission control. Appendix A provides NO_x emissions for large MWCs and an estimate of potential reductions, Appendix B provides characteristics of the large MWCs, and Appendix C details characteristics of small MWCs in the OTR. The workgroup performed some preliminary work to identify non-OTR MWC EGUs in the 48 contiguous states. The Results section provides an overview of findings, and Appendix D lists the MWCs outside of the OTR.

Developing an Emissions Inventory for the OTR MWCs

To develop inputs for the OTC Modeling Committee to use in air quality modeling, individual MWC permit limit NO_x emission concentrations in parts per million (ppmvd) were collected.² These permit limits were used to estimate NO_x mass emissions rates in pounds per million British thermal units (lb/MMBTU) using the provisions of 40 CFR Part 60 Appendix A Method 19 to convert from ppmvd to pounds per standard cubic foot (lb/scf). The workgroup subsequently used the provided F-factors to convert from lb/scf to lb/MMBTU. Method 19 provides conversion factors using F-factors for determining particulate matter (PM), sulfur dioxide (SO₂), and NO_x emission rates in mass per unit calorific value, i.e., lb/ MMBtu.³ Once inputs to the Method 19 calculation were gathered, the design capacity of the emission unit in MMBtu/hr was multiplied by the estimated lb/MMBTU emission rate to convert to a mass emission rate in pounds per hour (lb/hr).

Because these MWC units run practically all the time except for routine maintenance, the workgroup assumed these units operate continuously and used a consistent estimate of hours of operation per year across all emission units. The assumption of nearly constant operating levels of the MWCs was confirmed by examination of Energy Information Administration (EIA) fuel consumption data indicating nearly constant month-to-month fuel consumption over a year’s time. By converting lb/hr to tons per year, the workgroup was able to compare the actual tons of NO_x emitted per year relative to the permitted levels by using the same formula but inserting the permitted emission concentration in ppmvd. Appendix E provides a detailed description of the method used.

In addition to estimating tons per year of NO_x for air quality modeling, the estimated mass emissions were used by the MWC workgroup to develop a ballpark estimate of the potential tons of NO_x that could be reduced with the application of additional emissions controls.

¹ See The Energy Recovery Council, “2018 Directory of Waste to Energy Facilities” accessed at: <http://energyrecoverycouncil.org/wp-content/uploads/2019/10/ERC-2018-directory.pdf>.

² Throughout this report, the term ppmvd is used in reference to NO_x emissions concentrations. As background, ppm can be shown on a mass (ug/g, or ug/cubic meter) or volume (ul/l) basis. The unit “ppmvd” means that the concentration is on a volume basis. The ppmvd designation indicates that the associated values are on a dry basis (e.g. water vapor is not part of the sample), which provides consistency for comparing any two values, by ensuring that the value is corrected on a dry basis which eliminates the variability introduced by moisture content in the sample gas. This process is similar to correcting a measured value for O₂ content of the sample gas, such as x ppmvd @12% O₂.

³ EPA, “Method 19 - Sulfur Dioxide Removal and Particulate, Sulfur Dioxide and Nitrogen Oxides from Electric Utility Steam Generators,” see: [Method 19 - Sulfur Dioxide Removal and Particulate, Sulfur Dioxide and Nitrogen Oxides from Electric Utility Steam Generators | Air Emission Measurement Center \(EMC\) | US EPA](#).

Conducting a Literature Review to Identify Additional NOx Control Technologies

The MWC workgroup identified and reviewed engineering analyses that evaluated the technical potential to reduce NOx emission from MWCs. The workgroup first found studies that evaluated NOx reductions from large MWCs with similar configurations to those in the OTR. A pair of studies conducted by Trinity Consultants for two Covanta facilities in Virginia were evaluated.⁴ The studies used similar methodologies for both facilities. Another study conducted by Babcock Power Environmental for a Wheelabrator facility in Baltimore, Maryland was reviewed.⁵ Like many large MWCs in the region, all three facilities use selective non-catalytic reduction (SNCR) as their baseline NOx control technology. A brief summary of these studies is provided below and more detail on the studies can be found in the Results section.

Trinity Consultants Studies

The Trinity Consultants studies evaluated two Covanta facilities, one in Alexandria/Arlington, VA and the other in Fairfax, VA, that are subject to RACT requirements for the 2008 ozone standard. Four technologies were evaluated for these MWCs: 1) optimized SNCR; 2) a proprietary low NOx combustion system (LN™) developed by Covanta for its own facilities; 3) selective catalytic reduction (SCR); and 4) Very Low NOx (VLN)/SNCR combination.

Babcock Power Environmental

The Babcock Power Environmental Study was conducted for a Wheelabrator facility in Baltimore, Maryland. The purpose of this study was to provide a feasibility analysis for additional control of NOx emissions from the waste-to-energy facility. As with the Covanta facilities evaluated in the Trinity Consultants' studies, the Baltimore MWCs were equipped with SNCR systems. The study analyzed seven technologies: 1) advanced SNCR (ASNCR), 2) flue gas recirculation SNCR (FGR-SNCR), 3) FGR-ASNCR, 4) hybrid SNCR-SCR, 5) DeNOx catalytic filter bags, 6) optimized SNCR, and 7) tail end SCR systems. A technology vendor (Fuel Tech, Inc.) was hired to provide a more comprehensive analysis of SNCR and ASNCR system capabilities to augment Babcock Power Environmental's analysis.

Findings from the Trinity and Babcock Power studies are excerpted in the Results section of this report.

Other Resources

Additional papers, correspondence, and studies were evaluated for this report. They include:

- A North American Waste to Energy paper which evaluated the feasibility of a 100 ppmvd 24-hour NOx limit⁶
- Information from a Montgomery County Resource Recovery NOx optimization study⁷

⁴ Trinity Consultants, "Project Report Covanta Alexandria/Arlington, Inc., Reasonably Available Control Technology Determination for NOx," September 2017, and "Project Report Covanta Fairfax, Inc., Reasonably Available Control Technology Determination for NOx," September 2017.

⁵ Babcock Power Environmental, "Waste to Energy NOx Feasibility Study," Prepared for: Wheelabrator Technologies Baltimore Waste to Energy Facility Baltimore, MD, February 20, 2020.

⁶ White, M.; Goff, S.; Deduck, S.; Gohlke, O., "New Process for Achieving Very Low NOx," Proceedings of the 17th Annual North American Waste-to-Energy Conference, NAWTEC17, May 18-20, 2009.

⁷ HDR, "Montgomery County Resource Recovery Facility NOx Optimization," May 18, 2016.

- Recent stack test data from the Covanta Essex facility in New Jersey where LN™ technology was working in conjunction with a conventional SNCR system⁸

Small MWCs

No studies were found of small MWCs in the OTR, which are characterized by limited space for NO_x reduction technology installation. One study from South Korea was reviewed by the MWC workgroup. The study discusses computational fluid dynamics (CFD) modeling and actual test data for the application of SNCR on a small (50 ton per day) MWC.⁹ More information on the configuration of small MWCs and space limitations is provided in the following section.

Estimating Tons per Year of NO_x that Could Be Reduced with Further Controls

Using the classifications of MWCs in the region (Part 60 classifications) and the results of engineering studies found in the literature, the MWC workgroup estimated the potential for additional NO_x reductions at MWCs. As described in the literature review section above, several studies were identified and reviewed. The approach used in this estimation is described below.

Large MWCs:

Most of the large MWCs in the OTR are equipped with SNCR, which was the baseline technology in both the Trinity and Babcock studies. Improvements to these units could include enhancing or modifying the existing SNCR system as installed with better monitoring or better spray nozzles. Another approach that was described in a Babcock study involved retrofitting the entire system. Additional approaches were described in detail in the Babcock study.

Using the OTR MWC inventory Excel worksheet, the workgroup applied two control levels to the large MWCs in the region: 130 ppmvd and 105 ppmvd. These two levels were both assumed to be 30-day averages. It is important to note that the Trinity studies used for this analysis assumed 24-hour averaging periods, but not a 30-day averaging period. The Babcock study assumed a 30-day averaging period, though the report also concluded that a 24-hour limit of 110-125 ppmvd could be met as well through the utilization of ASNCR. In addition, one unit in operation in the region at the Covanta Montgomery facility in Maryland which utilizes LN™ has a permit limit of 105 ppmvd for a 30-day rolling average.

The workgroup identified 105 ppmvd NO_x on a 30-day averaging period as technically feasible for the large MWC units, based on the engineering analyses reviewed. The workgroup decided to use the same emission limit of 105 ppmvd over a 30-day average for nearly all large MWCs in the region, assuming that the control technologies evaluated in the studies can achieve this limit among nearly all large MWCs. This is the 30-day average value for ASNCR from the Babcock study. Like ASNCR, Covanta's Low NO_x Technology is also able to meet a 30-day average of 105 ppmvd (e.g. the Covanta Montgomery facility in Maryland). This provides a consistent 30-day limit that is obtainable for the Covanta and Wheelabrator facilities. To the extent that the estimated emission reduction potential for some units is based on the permit limit values with 24-hour average periods, there is not a 1-to-1 comparison with the

⁸ Letter from the State of New Jersey to Michael Klein, dated March 14, 2019 in reference to Covanta Energy Group, Inc. Essex County Resource Recovery Facility – Newark Annual Stack Test Program.

⁹ Nguyen, T.D.B., *et al.*, "Application of urea-based SNCR to a municipal incinerator: On-site test and CFD simulation," Chemical Engineering Journal 152 (2009) 36-43.

recommended limit of 105 ppmvd on a 30-day average unless the averaging time differences are accounted for.

In addition to researching the potential for a 30-day averaging period NOx limit, the workgroup evaluated the potential for a 24-hour averaging period NOx limit. The workgroup researched existing facilities permitted to a 110 ppmvd standard, read literature on technical feasibility and capital costs, and evaluated potential operating and maintenance costs associated with a more stringent 24-hour standard.

For both a 30-day and 24-hour NOx ppmvd averaging period, the workgroup researched and compiled implementation examples of MWCs that have been retrofitted with technologies to achieve the lower NOx limits.

Excluded Large MWCs:

There were large MWCs in the region that were also equipped with SNCR but were excluded from the estimation of NOx reductions. Two examples are the Wheelabrator Saugus units in Massachusetts. Due to the physical constraints of the two existing MWC units at this facility, the 105 ppmvd 30-day average NOx limit was not assumed to be achieved without major modifications of the existing MWCs. The Saugus MWCs are a vintage European design that incorporates a low profile “tail-end boiler” configuration with a single pass short waterwall furnace. The older tail end design and short furnace limits the ability to install additional cost-effective NOx controls.

Small MWCs

Small MWCs located in the OTR tend to utilize rotary combustors or modular combustors of either the starved air or excess air configurations. While some small MWCs of these configurations incorporate some NOx control provision in their original design, little recent information was located discussing the technical or economic feasibility of retrofitting additional or more modern NOx controls on such units. The exception was the study conducted in South Korea (see footnote 9). For the MWC in the South Korean study, a NOx reduction of 70 percent was found to be feasible. This percentage reduction is similar to that found in the literature for large MWCs with the installation of ASNCR. However, due to the limited number of small MWCs in the OTR and the sparsity of public information regarding the technological and economic feasibility of advanced controls, the MWC workgroup was unable to recommend NOx emission rate limitations more stringent than the values already permitted.

The possibility of additional control for these small MWCs, as demonstrated in non-US applications, should be considered in the event additional sources of NOx reductions become necessary. Conducting additional research on small MWCs is a potential area for additional research since further review of the literature may yield more information on the potential to reduce emissions from these units. A list of these units is provided in Appendix C.

The MWC workgroup attempted to collect available actual measured flow rates captured by continuous emission monitors (CEM) in the OTR. However, very little CEM data was found to use in a comparison with permit or RACT emission levels to determine the extent to which MWCs in the region are over-complying with regulated emissions limits and to determine opportunities for lowering emissions limits.

Researching the Potential Costs of Further MWC NO_x Controls

The MWC workgroup relied on the Trinity and Babcock studies described above for example NO_x control technology costs in this pilot study. In addition, the workgroup used costs found in an EPA document: Chapter 2 - Cost Estimation: Concepts and Methodology¹⁰ to fill in gaps in cost data. Last, the workgroup used information from EPA's NSR Guidance document to estimate urea consumption-related operating costs.¹¹

The pair of studies by Trinity Consultants (described in previous sections) for the Covanta MWCs located in Alexandria/Arlington and Fairfax, VA were first evaluated. The Covanta facilities were equipped with SNCR at the time of the RACT analysis and costs were evaluated for adding three additional potential technologies: 1) the proprietary low NO_x combustion system (LNTM) developed by Covanta for its own facilities; 2) selective catalytic reduction (SCR); and Very Low NO_x (VLN)/SNCR combination.

In the analysis for the SCR costs, Covanta solicited bids from engineering, procurement, and construction companies to determine system costs. The SCR system included the SCR reactor; gas-to-gas recuperative heat exchanger; steam coil heater; reagent feed injection and mixing system; and all associated support steel, piping, and controls. The consultants were instructed to design the SCR to receive NO_x at 90-180 ppmvd (24-hour average) and control it to 50 ppmvd (24-hour average). Direct and indirect annual operating costs were obtained from a BACT analysis of an MWC in West Palm Beach, Florida.¹²

Capital costs for installation of the LNTM process were estimated by examining each of the boilers at the facility and costs were developed on a per-boiler basis. The installation cost, which includes items such as fans, dampers, ducting, and process controls, was estimated based on actual expenses from another Covanta facility (Montgomery County, MD). The annual costs were scaled linearly from the Montgomery County project costs to the Covanta facilities in Virginia.

Total capital investment costs were provided in both Covanta studies, including direct costs (purchased equipment) and indirect costs (installation costs and lost production due to extended downtime for installation). Direct and indirect costs were also presented for annual operating costs.

The third study was the Babcock Power Environmental analysis conducted for the Wheelabrator facility in Baltimore. Capital and operating costs were evaluated for each technology. At the Baltimore facility, each of the three MWCs is equipped with SNCR. As mentioned above, the study analyzed advanced SNCR (ASNCR), FGR-SNCR that incorporates flue gas recirculation into the SNCR design, FGR-ASNCR, hybrid SNCR-SCR, DeNO_x catalytic filter bags, and tail end SCR systems. Because Covanta's Low NO_x combustion system is proprietary technology, it was not considered for the Wheelabrator facility in Baltimore. For each of these technologies, Babcock Power Environmental estimated costs for materials, equipment, and installation. A technology vendor (Fuel Tech, Inc.) was hired to provide a more comprehensive analysis of SNCR and Advanced SNCR (ASNCR) system capabilities to augment Babcock's analysis. In this study, annualized capital costs were not provided and so the MWC workgroup estimated

¹⁰ EPA, "Economic and Cost Analysis for Air Pollution Regulations," [Chapter 2 - Cost Estimation: Concepts and Methodology](#), last updated in February 2018.

¹¹ EPA NSR Guidance Document, 2019, <https://www.epa.gov/sites/production/files/2017-12/documents/snrcostmanualchapter7thedition20162017revisions.pdf>.

¹² Florida Department of Environmental Protection "Written Notice of Intent to Issue a Permit," "Public Notice of Intent to Issue Air Permit," "Technical Evaluation and Preliminary Determination," "Draft Permit with Appendices" November 2010.

these costs from a formula in the EPA document: Chapter 2 - Cost Estimation: Concepts and Methodology (see footnote 10).

To estimate the costs per ton of NO_x reduced assuming a 24-hour NO_x limit, the workgroup relied on the Trinity and Babcock Power studies. The workgroup made some adjustments to these costs. First, the workgroup estimated tons of NO_x reduced each year using the 110 ppmvd limit. Operating cost adjustments were made to account for the fact that the Trinity study evaluated a 90 ppmvd annual NO_x limit and the workgroup was estimating costs for a 110 ppmvd 24-hour limit. To adjust operating costs, the workgroup estimated the difference in cost for urea between the 90 ppmvd NO_x annual limit and a 110 ppmvd 24-hour averaging period. The cost for urea consumption for NO_x removal was performed in two ways. First, the cost estimate on a per lb of NO_x reduction was developed using information in the Wheelabrator Baltimore study. The differences between the optimized SNCR and advanced SNCR control options were evaluated. The second estimation method was based on simple chemical reaction estimates available in guidance from EPA, and urea cost values from the Wheelabrator Baltimore study. Details of the utilized estimation methodologies are found in Appendix G. Additional information on how costs were developed in the RACT studies that the MWC workgroup relied on is provided in the next section.

The MWC workgroup anticipates the control technologies and associated costs found in the literature would apply to most of the MWCs throughout the OTR. However, additional analyses may be needed to further refine these estimates for specific MWCs.

Findings

In this section, an inventory of MWC units and NO_x emissions in tons per year, a summary of technologies to reduce NO_x from MWCs, an estimate of the NO_x emission reduction potential for OTR MWCs, and estimated costs for installing and operating additional technologies are provided.

OTR MWC Inventory of Units and NO_x Emissions

The inventory of MWC units in the OTR is summarized in Table 1. A total of 103 large and small units are operating in the nine OTR states with MWCs. In 2018, large units emitted over 21,000 tons of NO_x annually and small units emitted approximately 900 tons of NO_x. Missing from this analysis are a few MWCs in the region for which the MWC workgroup could not calculate annual NO_x emissions. This is a minor portion of the inventory and could be estimated in a follow-on analysis.

Table 1: Summary of OTR MWCs and NOx Emissions by State

State	Number of Large Units	Number of Small Units	Annual Tons of NOx Emissions - Large Units (2018)	Annual Tons of NOx Emissions - Small Units (2018)
Connecticut	12	0	2,226	0
Maine	4	2	670	278
Maryland	6	0	1,435	0
Massachusetts	11	6	4,754	173
New Hampshire	2	0	344	0
New Jersey	11	0	2,044	0
New York	13	5	3,998	456
Pennsylvania	19	0	3,531	0
Virginia	7	0	2,276	0
Total	90	13	21,278	906

As can be seen from Table 1, large MWCs emit most of the NOx pollution from MWCs in the OTR. As mentioned above, information was found in the literature on additional NOx control technologies for the types of MWCs in the “large” category. For these reasons, the MWC workgroup focused its attention on technologies to reduce NOx emissions from large MWCs.

Technologies to Reduce NOx from MWCs in the OTR

Information is provided below on the potential to reduce NOx emissions from MWCs in the OTR. First, excerpts from the Trinity Consultants’ report describing the technologies and the potential NOx reductions that can be achieved using each of the technologies on Covanta facilities are provided, followed by information from the Babcock Power study on a Wheelabrator facility. Additional information on the technologies is available in Appendix F.

Covanta patented low NOx technology (LN™)

Covanta has developed a proprietary low NOx combustion system that involves staging of combustion air. The system is a trademarked system and Covanta has received a patent for the technology. Secondary air (also called overfire air) is injected through nozzles located in the furnace side walls immediately above the grate creating turbulent mixing to complete the combustion process. The Covanta LN™ process modifies the secondary air stream. A new series of air nozzles are installed higher in the furnace (tertiary air) and a portion of the secondary air is diverted to these new nozzles. The distribution of air between the primary, secondary, and tertiary streams is then controlled to yield the optimal gas composition and temperature to minimize NOx formation and control combustion. The tertiary air achieves complete coverage of the furnace cross-section to ensure good mixing with the combustion gases. Note that the total air flow to the MWC is not changed, only the distribution of air is changed. The LN™ combustion system works in concert with an optimized SNCR system to achieve lower NOx emissions. The LN™ process can be retrofitted to an existing unit, and Covanta has installed the LN™ process at approximately 20 units worldwide. The LN™ process can appreciably increase annual maintenance costs due to increased refractory wear and boiler fouling.

The Trinity report found that implementation of LN™ can reasonably achieve an annual NOx emission limit of 90 parts per million volume dry (ppmvd) (7% O₂) and a daily NOx limit of 110 ppmvd (7% O₂). LN™ is used in combination with SNCR and is thus presented considering usage of the combustion technology plus SNCR.

SCR

Trinity Consultants instructed its subcontractors to design a SCR system that included the SCR reactor; gas-to-gas recuperative heat exchanger; steam coil heater; reagent feed injection, and mixing system; and all associated support steel, piping, and controls. The consultants were instructed to design the SCR to receive NOx at 90-180 ppmvd (24-hour average) and control it to 50 ppmvd (24-hour average). The study concluded there are significant space considerations with SCR system installation which can be managed in a cost-effective way in a new development, but which make retrofit installation very costly and complex. Specifically, the piping, wiring, supports, and other hardware require substantial space which may not be available in an existing facility.

VLN Technology

The Very Low NOx (VLN) system employs a unique combustion air system design, which in addition to the conventional primary and secondary air systems, features an internal gas recirculation injection system. Recirculation of the flue gas reduces the need for combustion air for complete combustion in the furnace. The combination of the internal gas recirculation and reduced secondary air extends the combustion zone in the furnace, which in turn inhibits the formation of NOx. A NOx limit of 110 ppmvd NOx on a 24-hour average basis and 90 ppmvd on an annual basis was found to be feasible. The study concluded that VLN remains a viable technology for new MWC units but is not technically feasible for an existing unit.

Babcock Power Environmental Study

The Babcock Power Environmental Study was conducted for a Wheelabrator facility in Baltimore, Maryland. The purpose of this study was to provide a feasibility analysis for additional control of NOx emissions from the waste-to-energy facility. The Baltimore MWCs were equipped with an SNCR system. Results from the analysis conducted for the study are provided below for each of the technologies evaluated.

Optimized SNCR

The study analyzed CFD model outputs and found that through adjustments to residence time, NOx emissions levels of 135 ppmvd @7% O₂ on a 24-hour block average and 130 ppmvd @7% O₂ on a 30-day rolling average are achievable.

Advanced-SNCR (ASNCR)

The Babcock Power Environmental study evaluated optimized injector locations. It concluded this option is technically feasible with future CFD and chemical spray modeling where particular attention is paid to injector placement so that there is no risk of chemical impingement on the superheater and boiler surfaces. The study concluded that a reduction of 25 ppmvd @7% O₂ on a 30-day rolling average (i.e., 105 ppmvd) can be realized over the optimized existing SNCR. In discussing the potential retrofit of ASNCR, the report states “based on experience ... a 5% improvement in chemical coverage is feasible, leading to a target NOx of 110 ppmvd @7% O₂ on a 24-hour block average and 105 ppmvd @7% O₂ on a 30-day rolling average while the ammonia slip is kept at the 5 ppm range.”

ASNCR NO_x control technology may be considered for retrofit on existing MWCs as either a new retrofit technology or a significant upgrade to an existing SNCR. ASNCR is like SNCR in that it utilizes the injection of reagents into the proper temperature zones of the furnace to reduce the flue gas NO_x concentration. ASNCR designs may utilize advanced computer modeling techniques to specify SNCR nozzle locations and elevations so that their operation may be optimized across varying furnace conditions. The primary difference between a well-designed SNCR and ASNCR system is that ASNCR would utilize advanced furnace temperature monitoring instrumentation to provide near real time operating furnace temperature profiles. This information allows the control system to modulate which ASNCR injectors are in operation and to automatically adjust the individual injector flow rate in order to optimize the overall NO_x emission rate. This advanced system optimizes the NO_x reduction chemical reaction across the furnace to achieve high levels of overall NO_x reduction while maintaining low ammonia slip.

ASNCR is an effective NO_x reduction technology capable of achieving a 70% reduction. Industry literature discusses that for most large MWC EGUs, uncontrolled NO_x emission rates are in the range of 300 ppmvd to 350 ppmvd @7% O₂. Based on these values, it would appear that a general range of NO_x emissions utilizing ASNCR would be 90 ppmvd to 105 ppmvd.

The Babcock Power Environmental information suggests that ASNCR may be applicable to many MWCs as a retrofit technology, although furnace configuration or other factors could affect the NO_x reduction potential.

FGR-SNCR

With this option, Flue Gas Recirculation is incorporated into the SNCR design. The FGR-SNCR option was evaluated using a boiler heat transfer model. In this option, a portion of the flue gas from combustion is recirculated from the fan inlet duct and re-injected back into the furnace through the over-fire air system. FGR is used to replace a portion of the secondary air flow. This reduces use of ambient air, and therefore provides additional NO_x emission reduction by reducing O₂ concentration or excess ambient air and combustion temperature, while still maintaining the secondary air gas flow needed for mixing in the furnace.

FGR-ASNCR

It is also possible to combine the FGR technology with the ASNCR technology. The implementation of ASNCR by adding additional independent zones of injection and an acoustic pyrometer can provide additional NO_x reduction while controlling the ammonia slip. The FGR-ASNCR system was evaluated using a boiler heat transfer model. The study concluded that FGR-ASNCR is technically feasible from both an arrangement and performance perspective with future CFD modeling.

Hybrid SNCR-SCR

The Hybrid SNCR-SCR option utilizes two treatment stages: a SNCR treatment stage followed by a SCR treatment stage. In a stand-alone SNCR application, the reducing agent is released at higher temperatures to minimize ammonia slip formation. In hybrid applications, the ammonia slip becomes the reducing agent over the catalyst. The hybrid system was not considered to be technically feasible for the Baltimore facility.

DeNOx Catalytic Filter Bags

DeNOx catalytic filter bags can be utilized with ammonia injection to reduce NOx in a similar fashion to traditional SCR catalyst. These combination bags remove both dust and gaseous compounds simultaneously. The DeNOx catalyst was not considered to be technically feasible at the Baltimore facility due to operating temperature requirements.

Tail end SCR Systems

A tail end system positions the SCR downstream of all other air pollution control equipment installed on a unit. A major benefit of this installation location is that many of the flue gas constituents that would be damaging to the catalyst have been removed prior to the SCR reactor inlet. However, the installation location results in flue gas temperatures below the acceptable range for catalytic reduction, and the flue gas consequently must be reheated via natural gas or oil burners or steam coil heaters. Tail end SCR was not found to be technically feasible for a retrofit application in this study. While it is potentially technically feasible, it would require additional detailed evaluations to be performed to confirm feasibility for retrofits.

Implementation Examples of LN™ and ASNCR

The Covanta LN™ technology was installed at the Montgomery County, Maryland facility in 2009 and has been operational since then. The Montgomery County Resource Recovery Facility in Maryland is currently operating under a NOx RACT requirement which limits NOx emissions to 140 ppmvd @7% O₂ for a 24-hour block average. In 2009 Covanta, under an Agreement with the Northeast Maryland Waste Disposal Authority and the County, completed work on the installation of Covanta's LN™ combustion system upgrade to the SNCR system. Operational data (since the May 1, 2019 NOx RACT effective date) at the facility demonstrate that the units on average are able to achieve a daily average of around 84 ppmvd @7% O₂.

Maryland's NOx RACT also required a NOx 30-day rolling average emission rate of 105 ppmvd @7% O₂ to be met beginning on May 1, 2020. Since that time, the peak 24-hour average recorded has been on the order of 103 ppmvd @7% O₂. The facility is capable, and further demonstrates, meeting a 110 ppmvd 24-hour limit. Information from a Montgomery County Resource Recovery NOx optimization study found that ammonia slip is below 5 ppm for all units with LN™ technology with SNCR and with NOx emissions of 66 ppm and higher.

The Covanta LN™ is being installed at Covanta Alexandria/Arlington, Virginia and Covanta Fairfax, Virginia. For Covanta Alexandria/Arlington, the permit requires the facility to install the low NOx combustion system on the first unit by the end of the 4th quarter of 2019, the second unit by the end of the 4th quarter of 2020, and the third unit by the end of the 4th quarter of 2021.¹³ For Covanta Fairfax, the permit requires the facility to install the low NOx combustion system on the first unit by the end of the 2nd quarter of 2019, the second unit by the end of the 4th quarter of 2019, the third unit by the end of the 4th quarter of 2020, and the fourth unit by the end of the 4th quarter of 2021.¹⁴ Thus, both facilities will be completely utilizing the low NOx technology by the start of 2022.

¹³ Permit issued by the Commonwealth of Virginia to operate a municipal solid waste combustor at Alexandria, Virginia, dated February 2019.

¹⁴ Permit issued by the Commonwealth of Virginia to operate a municipal solid waste combustor at Fairfax, Virginia, dated February 2019.

The Virginia Department of Environmental Quality has determined that Covanta’s proprietary Low NOx technology is RACT for Covanta MWCs. The Virginia facilities are permitted to emit 110 ppmvd of NOx on a 24-hour average basis @7% O₂, and 90 ppmvd of NOx on an annual average basis @7% O₂.¹⁵ In addition, the limits of 110 ppmvd @7% O₂ on a daily average and 90 ppmvd @7% O₂ on an annual average have been adopted into The Commonwealth of Virginia’s SIP as RACT for the 2008 ozone NAAQS for both of these facilities.¹⁶

Table 2 lists details for facilities that have permitted NOx emission rate limits of 110 ppmvd @7% O₂, 24-hour average. Public information indicates all have been retrofit with the proprietary Covanta Low NOx (LN™) modifications in conjunction with SNCR. The boiler/combustion units are of three different manufacturers and range in rating from 325 tons/hr to 750 tons/hr.

Table 2: List of Facilities with Retrofit NOx Controls Permitted at 110 ppmvd 24-hour Average

Plant Name	State	Combustor Manufacturer	Rating (tons/day)	NOx Control	Permit Short Term NOx Limit*,**	Permit Long Term NOx Limit*,***
Covanta Alexandria/Arlington Energy	VA	Keeler/Dorr-Oliver	325	Covanta LN, SNCR	110	90
Covanta Alexandria/Arlington Energy	VA	Keeler/Dorr-Oliver	325	Covanta LN, SNCR	110	90
Covanta Alexandria/Arlington Energy	VA	Keeler/Dorr-Oliver	325	Covanta LN, SNCR	110	90
Covanta Fairfax Energy	VA	Ogden Martin	750	Covanta LN, SNCR	110	90
Covanta Fairfax Energy	VA	Ogden Martin	750	Covanta LN, SNCR	110	90
Covanta Fairfax Energy	VA	Ogden Martin	750	Covanta LN, SNCR	110	90
Covanta Fairfax Energy	VA	Ogden Martin	750	Covanta LN, SNCR	110	90
Hillsborough County Resource Recovery	FL	Riley w/Martin GMBH Grates	690	Covanta LN, SNCR, FGR	110	90

* ppmvd @7% O₂

** permit short term limit averaging period is 24-hour

*** permit long term limit averaging period is annual

The information in Table 2 indicates that many of the Covanta run facilities, across a wide range of sizes and manufacturers, can be retrofitted with the proprietary Covanta LN™ technology and achieve

¹⁵ See footnotes 16 and 17 for sources.

¹⁶ Submittal to EPA Region III for a SIP revision by the Commonwealth of Virginia entitled, “Statement of Legal and Factual Basis, Covanta Alexandria/Arlington, Permit No. NRO-RACT 71895,” February 2019 and “Statement of Legal and Factual Basis, Covanta Fairfax, Permit No. NRO-RACT 71920,” February 2019.

significant NOx reductions. That a number of these units have been retrofitted with the LN™ technology and have been permitted at 110 ppmvd @7% O₂ 24-hr average supports a proposed 110 ppmvd 24-hr avg NOx rate limit. Furthermore, data on Covanta Fairfax's website (<https://www.covanta.com/where-we-are/our-facilities/fairfax>) shows the facility is consistently able to achieve a daily average of around 90 ppmvd @7% O₂ for Units 2 and 4.

A number of additional facilities are retrofitted with LN™ but not permitted to 110 ppmvd. These include:

- The Montgomery County facility described previously.
- The Covanta Essex facility in New Jersey has achieved values around 100 ppmvd @7% O₂.¹⁷ This is based on recent stack test data.
- There is limited information available that technology similar to LN™ has been installed on a Covanta operated MWC in the mid-west that is said to be operating at 90 ppmvd @7% O₂ annual average (similar to the annual limits for the units that are now permitted at 110 ppmvd 24-hr). However, the publicly available information indicates that the unit is operating at the low NOx level by contract, not by permit limit.

A North American Waste to Energy paper discussing the retrofit potential of Covanta's proprietary VLN and LN technologies on an existing Covanta operated MWC found that a 100 ppmvd 24-hour limit is feasible. The paper provided an overview of a MWC development and demonstration project and provided NOx and ammonia (NH₃) slip data. The paper discussed the extended operating experience that has been established on the system.

ASNCR technology is being installed at a Baltimore City, MD facility. The schedule for implementing the technology is as follows: permits must be in place by the end of 2021 for the three units, followed by construction in 2022, and the facilities must be on-line in 2023.

Potential NOx Reductions Resulting from Installing Additional Control Technologies

Using the methods described in previous sections, the MWC workgroup estimated that approximately 7,200 tons of NOx could be reduced in the OTR with a 105 ppmvd 30-day average NOx requirement for MWCs. The results are summarized in Table 3. The workgroup also evaluated a 130 ppmvd 30-day average NOx requirement. Not shown in the table, a 130 ppmvd 30-day average limit was estimated to reduce NOx by 3,600 tons per year.

Table 3: Summary of Potential NOx Reductions from MWCs in the OTR

Type of unit	2023 Projected NOx Emissions (tons/yr)	Potential 2023 NOx Reduction (tons/yr) Assuming 105 ppmvd	Percent Reduction from 2023 Projected NOx Emissions
Large MWC	22,992	7,290	32%
Small MWC	1,006	Not estimated	Not estimated
Total	23,998	7,290	30%

¹⁷ Letter from the State of New Jersey to Michael Klein, dated March 14, 2019 in reference to Covanta Energy Group, Inc. Essex County Resource Recovery Facility – Newark Annual Stack Test Program.

An OTR-wide estimate of potential tons of NOx reduced assuming a 24-hour NOx limit of 110 ppmvd was not estimated in this study, however, tons of NOx reduced on an annual basis would be in the range of the reductions shown in column three of Table 3.

Control Costs

As discussed in the Method section, the MWC workgroup researched studies to identify costs associated with the installation and operation of additional NOx control technologies on MWCs in the region. Three studies were found with detailed cost information for MWCs that are similar in configuration to a significant number of large MWCs in the region. The results of cost analyses from these studies are provided in this section.

Results from the Trinity Consultants analysis of installation of a proprietary Covanta Low NOx technology and SCR at Covanta facilities are shown in Table 4. SCR was estimated to be very costly (\$31,000 per ton of NOx reduced), therefore the results for that technology are not presented here. The left column lists types of costs (such as capital or operating costs) and NOx emissions information for the Alexandria/Arlington VA facility. The middle column provides emission information for the baseline technology (SNCR). No costs are provided in this column since SNCR is already in operation at the facility. The right column provides costs associated with installing the Low NOx technology to the MWC and the resulting NOx emissions changes.

Table 4: Cost of Installing Low NOx Technology on an MWC with SNCR (Alexandria/Arlington, VA)

	SNCR (Base)	Low NOx
Capital Costs (\$)	-	\$1,018,705
Annual Operating Costs (\$)	-	\$213,773
Annualized Capital Costs (\$)	-	\$116,533
Projected Lifetime (yr)	-	20
Interest Rates (%)	-	7%
Total Yearly Costs (\$)	-	\$330,306
Base Case NOx (ppmvd)*	180	180
Controlled NOx (ppmvd)	180	90
Estimated NOx Reduction (%)	0	50
NOx Emission (ton/yr)	165	82.5
Emission Reduction (ton/yr)	0	82.5
Cost Effectiveness (\$/ton)	\$0.00	\$4,004

*This is an “equivalent” NOx emissions rate, rather than a permit level.

The analysis shows that equipping the Covanta unit with Low NOx technology resulted in a 50 percent NOx reduction at a cost of approximately \$4,000 per ton of NOx reduced.

The row labeled “Base Case NOx (ppmvd)” shows the permit limit before installation of Covanta's Low NOx Technology and the “Controlled NOx (ppmvd)” is the new annual permit limit after installation of the Low NOx technology. The table shows that NOx emissions were reduced from 180 ppmvd to 90 ppmvd with the installation of the Low NOx technology.¹⁸ The row labeled “NOx Emission (ton/yr)” shows NOx emissions before and after installation of Covanta’s Low NOx technology. The NOx emission

¹⁸ Unless stated otherwise, all concentrations listed in this report assume 7% O₂.

reduction in tons per year is calculated to be 82.5 tons per year as shown in the next row. The “Cost Effectiveness” value assumes that SNCR was already installed at the facility and thus assigns zero additional cost to the facility.

The total capital investment or “Capital Costs” includes direct and indirect costs. Direct costs are purchased equipment costs and indirect costs are costs associated with installation of equipment and lost revenue due to extended downtime for installation.

The study also estimated direct and indirect costs for annualized expenditures. Direct costs in this category include increased capital expenditures due to the Low NOx technology and increased annual expenses from operating the equipment. Indirect operating costs are annualized capital costs such as administrative charges plus capital recovery (loan interest). Note that control costs are facility-specific, so any costs specified here are examples only.

Table 5 shows a similar analysis for the Covanta Fairfax, Virginia facility. In the Trinity Consultants analysis for the Fairfax facility, capital costs (\$1,564,242) were approximately 50 percent higher than for the Alexandria/Arlington facility. Operating costs (\$493,322) were 130 percent higher than those for the Alexandria/Arlington facility. The cost effectiveness (\$/ton of NOx reduced) for Fairfax was lower than in the Alexandria/Arlington MWC at \$2,888 per ton of NOx reduced. This is because the NOx emissions from the Fairfax MWC are considerably higher than in the example shown in Table 4. While both facilities realized a 50 percent reduction in NOx emissions from the installation of Low NOx technology, the MWC in Fairfax had a 230 ton annual NOx reduction while the Alexandria/Arlington facility realized an 83 ton NOx reduction annually for a capital cost that was 50 percent lower.

Table 5: Cost of Installing Low NOx Technology on an MWC with SNCR (Fairfax, VA)

	SNCR (Base)	Low NOx
Capital Costs (\$)	-	\$1,564,242
Annual Operating Costs (\$)	-	\$493,322
Annualized Capital Costs (\$)	-	\$178,938
Projected Lifetime (yr)	-	20
Interest Rates (%)	-	7%
Total Yearly Costs (\$)	-	\$672,260
Base Case NOx (ppmvd)	180	180
Controlled NOx (ppmvd)	180	90*
Estimated NOx Reduction Factor	0	0.5
Estimated NOx Reduction (%)	0	50
NOx Emission (ton/yr)	465.6	465.6
Projected Controlled NOx Emissions (ton/yr)	465.6	232.8
Emission Reduction (ton/yr)	0	232.8
Cost Effectiveness (\$/ton)	\$0.00	\$2,888

*annual average

Cost Estimate for a 24-Hour NOx Limit of 110 ppmvd using LN™

In this section, the workgroup’s estimate of capital and operating costs for using LN technology to achieve a 24-hour NOx limit of 110 ppmvd is presented. Tables 6 and 7 show estimates for the cost of installing and operating LN™ at Covanta facilities. In the far-right columns in the tables, labeled “Low

NOx Trinity Consultants Study,” costs and cost effectiveness numbers are taken from the Trinity Consulting study of the Alexandria/Arlington and Fairfax, VA Covanta facilities. The analysis evaluated an annual limit of 90 ppmvd for the facilities. The third column labeled “Low NOx Workgroup” provides an estimate developed by the MWC workgroup of dollars per ton of NOx reduced assuming a 24-hour limit using the costs from the Trinity study.

Table 6: Cost of Installing Low NOx Technology on an MWC with SNCR (Alexandria/Arlington, VA)

	SNCR (Base)¹	Low NOx – Workgroup²	Low NOx³
Capital Costs (\$)³	-	\$1,018,705	\$1,018,705
Cost Reduction for Assuming 110 ppmvd (\$)⁴		\$32,627	
Annual Operating Costs (\$)	-	\$181,146	\$213,773³
Annualized Capital Costs (\$)³	-	\$116,533	\$116,533
Projected Lifetime (yr)	-	20	20
Interest Rates (%)	-	7%	7%
Total Yearly Costs (\$)	-	\$297,679	\$330,306
Base Case NOx (ppmvd)⁵	180	180	180
Controlled NOx (ppmvd)⁶	180	110	90
Estimated NOx Reduction Factor	0.0	0.389	0.5
Estimated NOx Reduction (%)	0	38.89	50
NOx Emission (ton/yr)⁵	165	165	165
Projected Controlled NOx Emissions (tons/yr)	165	100.83	82.5
Emission Reduction (ton/yr)	0	64.17	82.5
Cost Effectiveness (\$/ton)⁷	\$0.00	\$4,639	\$4,004

¹SNCR was already installed at both facilities; assume \$0 additional cost to facilities

²The Workgroup’s recommendation and cost estimate

³Based on Covanta’s “Reasonably Available Control Technology Determination for NOx” for Covanta Alexandria/Arlington, VA

⁴Savings based on \$0.89 per pound of NOx reduced (from Babcock report for Wheelabrator Baltimore)

⁵NOx emissions before installation of Covanta’s Low NOx Technology

⁶New annual permit limit (@7% O₂)

⁷The Commonwealth of VA has determined that Low NOx Technology is RACT for the Alexandria and Arlington facilities

The O&M costs from the Trinity study assume use of reagent and other substances required to meet the 90 ppmvd annual average limit, as well as maintenance costs. Using these costs to calculate cost effectiveness values (\$/ton) for an assumed 110 ppmvd NOx 24-hour average limit could result in higher costs than would be incurred in actual use for the 110 ppmvd limit. This is because reagent and other substances required to meet the 90 ppmvd limit may be higher than that of O&M costs to achieve the 110 ppmvd 24-hour limit. Thus, using the method previously described, the workgroup adjusted the O&M costs and this is reflected in the “Annual Operating Costs” row in Tables 6 and 7.

The workgroup’s estimate of a 110 ppmvd 24-hour NOx limit cost effectiveness is \$4,639 per ton of NOx reduced. This is approximately \$600 per ton higher than the 90 ppmvd annual NOx limit in the Trinity study. The difference in cost effectiveness (in \$/ton of NOx removed) is primarily due to a lower estimated number of tons of NOx removed with the recommended NOx emission rate limit while assuming similar capital expenses associated with both rate limits. Note however that the estimated

annual O&M expenses would be somewhat lower for the recommended 110 ppmvd limit primarily due to a reduction in reagent consumption.

Table 7 provides a similar calculation using the Fairfax, VA Covanta cost evaluation from the Trinity study.

Table 7: Cost of Installing Low NOx Technology on an MWC with SNCR (Fairfax, VA)

	SNCR (Base)¹	Low NOx – Workgroup²	Low NOx³
Capital Costs (\$) ³	-	\$1,564,242	\$1,564,242
Cost Reduction for Assuming 110 ppmvd (\$) ⁴		\$92,079	
Annual Operating Costs (\$)	-	\$401,243	\$493,322 ³
Annualized Capital Costs (\$) ³	-	\$178,938	\$178,938
Projected Lifetime (yr)	-	20	20
Interest Rates (%)	-	7%	7%
Total Yearly Costs (\$)	-	\$580,181	\$672,260
Base Case NOx (ppmvd) ⁵	180	180	180
Controlled NOx (ppmvd) ⁶	180	110	90
Estimated NOx Reduction Factor	0.0	0.389	0.5
Estimated NOx Reduction (%)	0	38.89	50
NOx Emission (ton/yr) ⁵	465.6	465.6	465.6
Projected Controlled NOx Emissions (tons/yr)	465.6	284.53	232.8
Emission Reduction (ton/yr)	0	181.07	232.8
Cost Effectiveness (\$/ton) ⁷	\$0.00	\$3,204	\$2,888

¹ SNCR was already installed at both facilities; assume \$0 additional cost to facilities.

² The Workgroup's recommendation and cost estimate.

³ Based on Covanta's "Reasonably Available Control Technology Determination for NOx" for Covanta Alexandria/Arlington, VA.

⁴ Savings based on \$0.89 per pound of NOx reduced (from Babcock report for Wheelabrator Baltimore).

⁵ NOx emissions before installation of Covanta's Low NOx Technology.

⁶ New annual permit limit (@7% O₂).

⁷ The Commonwealth of VA has determined that Low NOx Technology is RACT for the Alexandria and Arlington facilities.

The cost per ton of NOx reduced in the 110 ppmvd 24-hour limit case (third column) is \$3,204. The method used to develop this estimate is the same as used in Table 6 for the Covanta Alexandria/Arlington facility.

As mentioned previously, the Babcock Power Environmental study for Wheelabrator evaluated four technologies: optimized SNCR, ASNCR, FGR-SNCR, and FGR-ASNCR. The baseline technology in this Wheelabrator facility was SNCR. Costs for converting this Wheelabrator facility to the different technology configurations are provided in Table 8.

The capital costs shown in Table 8 were taken from the Babcock study for the Wheelabrator Baltimore facility. "Annualized Capital Costs" are based on a formula from the EPA document: Chapter 2 - Cost Estimation: Concepts and Methodology. "Interest Rates" and "Projected Lifetime" are based on

Covanta's NOx RACT Analysis in Virginia for Covanta Fairfax and Covanta Alexandria/Arlington. "Current NOx Emissions" are based on 2023 estimates for NOx emissions from Wheelabrator Baltimore.

Table 8: Costs for Converting a Wheelabrator MWC with SNCR to Lower NOx Technology Configurations

	Optimized SNCR	ASNCR	FGR-SNCR	FGR-ASNCR
Capital Costs (\$)¹	\$85,200	\$8,665,162	\$5,829,591	\$12,993,524
Annual Operating Costs (\$)	\$695,000	\$995,000	\$815,000	\$1,035,000
Annualized Capital Costs (\$)	\$8,042	\$817,930	\$550,272	\$1,226,497
Projected Lifetime (yr)	20	20	20	20
Interest Rates (%)	7%	7%	7%	7%
Total Yearly Costs (\$)	\$703,042	\$1,812,9300	\$1,365,272	\$2,261,497
Base Case NOx (ppmvd)	150	150	150	150
Controlled NOx (ppmvd)	135	110	120	105
Estimated NOx Reduction Factor	0.100	0.267	0.20	0.30
Estimated NOx Reduction (%)	10.000	26.7	20	30
Current NOx Emission (tons/yr)	1,104	1,104	1,104	1,104
Projected Controlled NOx Emissions (tons/yr)	993.38	809.42	883.01	772.63
Emission Reduction (tons/yr)	110.38	294.34	220.75	331.13
Cost Effectiveness (\$/ton)	\$6,370	\$6,159	\$6,185	\$6,830

In Table 8, the "Base Case NOx" 24-hour permit limit is 150 ppmvd and the "Controlled NOx" limits for technologies are based on 24-hour block averages from Babcock Power Environmental study for Wheelabrator Baltimore.

Cost Summary

Cost evaluated for additional NOx controls ranged from \$2,888 to \$6,159 per ton of NOx reduced, depending on the technology and averaging period considered. While the costs presented in this section may be generally representative of the costs of upgrading other MWCs in the region with additional technology, further analysis would be required to determine an estimate for specific units. Nonetheless, the workgroup believes the costs reported in this section represent a reasonable estimate for further reducing NOx emissions from MWCs in the OTR.

Non-OTR MWCs

Available public data indicate there are 63 MWC EGU units in non-OTR contiguous states. Most of these 63 non-OTR MWCs would be categorized as large MWCs. The majority of these MWC EGUs are located in Florida (33 units), and the state with the next highest number of MWCs is Minnesota (nine units). Of the 63 non-OTR MWC EGUs, 12 are located in states linked to OTR state air quality. Permit NOx emission rate limits for these non-OTR MWCs (including those in linked states) are predominately within the range of the existing limits for OTR MWCs. While the non-OTR states were not contacted to obtain additional information from regulatory personnel most familiar with the non-OTR MWC, the publicly available information appeared to indicate that the range of configuration and operating characteristics

of these non-OTR MWCs were not dissimilar from the range of OTR MWCs. This suggests that these non-OTR MWCs would have emission reduction potentials, on an average MWC unit basis, similar to those estimated for the OTR MWC units. Because of the apparent low impact potential of the non-OTR MWCs due to number and geographic location, the workgroup did not quantify the emission reduction potential associated with the non-OTR MWCs. However, the fact that NO_x emission reductions appear to be technically and economically feasible from this class of sources in upwind states should not be forgotten if more detailed analysis of upwind source impact is undertaken. See Additional Research (below) for recommendations on additional actions.

Policy Implications

This pilot study of MWCs in the OTR finds a NO_x limit of 105 ppmvd (30-day average) could be achieved with the technologies described in this report in a cost-effective manner. In addition, the pilot concludes almost all large MWC facilities can be held to a 110 ppmvd @7% O₂ 24-hour NO_x limit. Thus, states that are updating RACT or NO_x permit limits for MWCs in the OTR should consider increasing the stringency of those emissions limits. At the federal level, the workgroup recommends SAS initiate a conversation with EPA on the introduction of similar requirements nationwide.

Additional Research

The Workgroup identified several areas for potential additional research. These are as follows:

- Conduct further research to determine whether any controls can be used on small MWCs. Since the workgroup had limited time to conduct its analysis, the group prioritized large MWCs. Some additional research could yield recommendations for these small units.
- Evaluate how peak day emissions could be reduced with either a 30-day averaging limit or a 24-hour limit.
- Conduct additional work to evaluate emissions from non-OTR MWCs.
- Initiate a dialogue with EPA on establishing nationwide MWC standards similar to the ones recommended in this pilot and to the extent possible conduct additional research to support this goal.

Conclusions

MWCs in the OTR are a significant source of NO_x emissions: in 2018, MWCs in the region emitted over 22,000 tons of NO_x. Significant annual NO_x reductions could be achieved from MWCs in the OTR using several different technologies as described in this report. The MWC workgroup concludes that a control level of 105 ppmvd on a 30-day average basis and a 110 ppmvd on a 24-hour averaging period are likely achievable for most large MWCs in the region. This conclusion is based on a review of engineering studies of similar MWCs in the OTR. Based on a projected 2023 NO_x inventory for the large MWCs in the region of approximately 23,000 tons, NO_x emissions from MWCs could be reduced by approximately 7,300 tons annually with additional controls achieving a 105 ppmvd level on a 30-day average. Approximately 4,000 tons of NO_x could be reduced with a permit limit of 130 ppmvd on a 30-day average. Studies evaluating MWCs similar in design to the large MWCs in the OTR found NO_x reductions could be achieved at a cost ranging from \$2,900 to \$6,600 per ton of NO_x reduced.

Appendix A: OTR Large MWC Actual and Proposed Emissions

Facility Name	State	Projected 2023 NOx Emissions (tons/yr)	Permit NOx Limit (ppmvd)*	130 ppmvd control level estimated NOx reduction (%)	130 ppmvd control level estimated NOx reduction (ton/yr)	105 ppmvd estimated control level NOx reduction (%)	105 ppmvd control level NOx estimated reduction (ton/yr)	2023 projected NOx (ton/yr) at 130 ppmvd	2023 projected NOx (ton/yr) at 105 ppmvd
Covanta Bristol Energy	CT	97	120	130 ppmvd is higher than permit	0	0	-12	97	84
Covanta Bristol Energy	CT	113	150	-13%	-15	-30%	-34	98	79
Covanta Southeastern Connecticut Company	CT	167	150	-13%	-22	-30%	-50	144	117
Covanta Southeastern Connecticut Company	CT	171	150	-13%	-23	-30%	-51	148	120
MIRA	CT	260	146	-11%	-28	-28%	-73	231	187
MIRA	CT	134	146	-11%	-15	-28%	-38	119	96
MIRA	CT	276	146	-11%	-30	-28%	-78	246	199
Wheelabrator Bridgeport	CT	301	150	-13%	-40	-30%	-90	261	211
Wheelabrator Bridgeport	CT	305	150	-13%	-41	-30%	-91	264	213
Wheelabrator Bridgeport	CT	310	150	-13%	-41	-30%	-93	269	217
Wheelabrator Lisbon	CT	117	150	-13%	-16	-30%	-35	101	82
Wheelabrator Lisbon	CT	126	150	-13%	-17	-30%	-38	109	88
Covanta Haverhill	MA	553	150	-13%	-74	-30%	-166	479	387
Covanta Haverhill	MA	586	150	-13%	-78	-30%	-176	508	410
SEMASS Resource Recovery	MA	426	146	-11%	-47	-28%	-120	379	306

Facility Name	State	Projected 2023 NOx Emissions (tons/yr)	Permit NOx Limit (ppmvd)*	130 ppmvd control level estimated NOx reduction (%)	130 ppmvd control level estimated NOx reduction (ton/yr)	105 ppmvd estimated control level NOx reduction (%)	105 ppmvd control level NOx estimated reduction (ton/yr)	2023 projected NOx (ton/yr) at 130 ppmvd	2023 projected NOx (ton/yr) at 105 ppmvd
SEMASS Resource Recovery	MA	486	146	-11%	-53	-28%	-136	432	349
SEMASS Resource Recovery	MA	498	146	-11%	-55	-28%	-140	443	358
Wheelabrator Millbury Facility	MA	500	150	-13%	-67	-30%	-150	433	350
Wheelabrator Millbury Facility	MA	472	150	-13%	-63	-30%	-142	409	331
Wheelabrator North Andover	MA	417	150	-13%	-56	-30%	-125	361	292
Wheelabrator North Andover	MA	447	150	-13%	-60	-30%	-134	387	313
Wheelabrator Saugus	MA	405	150	--	--	--	--	405	405
Wheelabrator Saugus	MA	388	150	--	--	--	--	388	388
Montgomery County Resource Recovery	MD	147	140	-7%		-25%	-37	147	110
Montgomery County Resource Recovery	MD	147	140	-7%		-25%	-37	147	110
Montgomery County Resource Recovery	MD	147	140	-7%		-25%	-37	147	110
Wheelabrator Baltimore Refuse	MD	367	150	-13%		-30%	-110	367	257
Wheelabrator Baltimore Refuse	MD	367	150	-13%		-30%	-110	367	257
Wheelabrator Baltimore Refuse	MD	367	150	-13%		-30%	-110	367	257

Facility Name	State	Projected 2023 NOx emissions (ton/yr)	Permit NOx limit (ppmvd)*	130 ppmvd control level estimated NOx reduction (%)	130 ppmvd control level estimated NOx reduction (ton/yr)	105 ppmvd estimated control level NOx reduction (%)	105 ppmvd control level NOx estimated reduction (ton/yr)	2023 projected NOx (ton/yr) at 130 ppmvd	2023 projected NOx (ton/yr) at 105 ppmvd
Penobscot Energy Recovery	ME	69.12	230	-43%	-30	-54%	-38	39	32
Penobscot Energy Recovery	ME	103.32	230	-43%	-45	-54%	-56	58	47
Ecomaine	ME	231.9	180	-28%	-64	-42%	-97	167	135
Ecomaine	ME	250.35	180	-28%	-70	-42%	-104	181	146
Wheelabrator Concord Facility	NH	218.09	205	-37%	-80	-49%	-106	138	112
Wheelabrator Concord Facility	NH	205.45	205	-37%	-75	-49%	-100	130	105
Camden Resource Recovery Facility	NJ	84.75	150	-13%	-11	-30%	-25	73	59
Camden Resource Recovery Facility	NJ	110.62	150	-13%	-15	-30%	-33	96	77
Camden Resource Recovery Facility	NJ	112.13	150	-13%	-15	-30%	-34	97	78
Covanta Essex Company	NJ	226.26	150	-13%	-30	-30%	-68	196	158
Covanta Essex Company	NJ	260.01	150	-13%	-35	-30%	-78	225	182
Covanta Essex Company	NJ	300.78	150	-13%	-40	-30%	-90	261	211
Union County Resource Recovery	NJ	204.55	150	-13%	-27	-30%	-61	177	143

Facility Name	State	Projected 2023 NOx emissions (ton/yr)	Permit NOx limit (ppmvd)*	130 ppmvd control level estimated NOx reduction (%)	130 ppmvd control level estimated NOx reduction (ton/yr)	105 ppmvd estimated control level NOx reduction (%)	105 ppmvd control level NOx estimated reduction (ton/yr)	2023 projected NOx (ton/yr) at 130 ppmvd	2023 projected NOx (ton/yr) at 105 ppmvd
Union County Resource Recovery	NJ	209.09	150	-13%	-28	-30%	-63	181	146
Union County Resource Recovery	NJ	216.8	150	-13%	-29	-30%	-65	188	152
Wheelabrator Gloucester LP	NJ	137.78	150	-13%	-18	-30%	-41	119	96
Wheelabrator Gloucester LP	NJ	126.77	150	-13%	-17	-30%	-38	110	89
Covanta Babylon Inc	NY	110.79	150	-13%	-15	-30%	-33	96	78
Covanta Babylon Inc	NY	111.78	150	-13%	-15	-30%	-34	97	78
Covanta Hempstead	NY	357.31	145.7 (lb/hr)	-29.7%	-106	43%	-155	357	203
Covanta Hempstead	NY	380.28	145.7 (lb/hr)	29.7%	-113	43%	-164	251	216
Covanta Hempstead	NY	465.8	145.7 (lb/hr)	29.7%	-138	43%	-201	267	264
Covanta Niagara I, LLC	NY	341.73	150	-13%	-46	-30%	-103	327	239
Covanta Niagara I, LLC	NY	378.41	150	-13%	-50	-30%	-114	328	265
Huntington Resource Recovery	NY	443 for all 3 units	185	185	-30%	-35	-43%	-50	82
Huntington Resource Recovery	NY	443 for all 3 units	185	185	-30%	-35	-43%	-50	82

Facility Name	State	Projected 2023 NOx emissions (ton/yr)	Permit NOx limit (ppmvd)*	130 ppmvd control level estimated NOx reduction (%)	130 ppmvd control level estimated NOx reduction (ton/yr)	105 ppmvd estimated control level NOx reduction (%)	105 ppmvd control level NOx estimated reduction (ton/yr)	2023 projected NOx (ton/yr) at 130 ppmvd	2023 projected NOx (ton/yr) at 105 ppmvd
Huntington Resource Recovery	NY	443 for all 3 units	185	-30%	-35	-43%	-50	82	66
Onondaga County Resource Recovery	NY	684.18	200	-35%	-239	-48%	-325	445	359
Onondaga County Resource Recovery	NY		200	-35%	0	-48%	0		0
Onondaga County Resource Recovery	NY		200	-35%	0	-48%	0		0
Wheelabrator Hudson Falls	NY	145.81	205	-37%	-53	-49%	-71	92	75
Wheelabrator Hudson Falls	NY	153	205	-37%	-56	-49%	-75	97	78
Wheelabrator Westchester	NY	411.93	184	-29%	-121	-43%	-177	291	235
Wheelabrator Westchester	NY	417.23	184	-29%	-122	-43%	-179	295	238
Wheelabrator Westchester	NY	459.57	184	-29%	-135	-43%	-197	325	262
Covanta Delaware Valley	PA	228.29	180	-28%	-63	-42%	-95	165	133
Covanta Delaware Valley	PA	240.23	180	-28%	-67	-42%	-100	173	140
Covanta Delaware Valley	PA	247.59	180	-28%	-69	-42%	-103	179	144
Covanta Delaware Valley	PA	253.87	180	-28%	-71	-42%	-106	183	148

Facility Name	State	Projected 2023 NOx emissions (ton/yr)	Permit NOx limit (ppmvd)*	130 ppmvd control level estimated NOx reduction (%)	130 ppmvd control level estimated NOx reduction (ton/yr)	105 ppmvd estimated control level NOx reduction (%)	105 ppmvd control level NOx estimated reduction (ton/yr)	2023 projected NOx (ton/yr) at 130 ppmvd	2023 projected NOx (ton/yr) at 105 ppmvd
Covanta Delaware Valley	PA	274.62	180	-28%	-76	-42%	-114	198	160
Covanta Delaware Valley	PA	275.95	180	-28%	-77	-42%	-115	199	161
Covanta Plymouth Renewable Energy	PA	440.65	180	-28%	-122	-42%	-184	318	257
Covanta Plymouth Renewable Energy	PA	445.72	180	-28%	-124	-42%	-186	322	260
Harrisburg Facility	PA	83.74	135	-4%	-3	-22%	-19	81	65
Harrisburg Facility	PA	84.22	135	-4%	-3	-22%	-19	81	66
Harrisburg Facility	PA	84.58	135	-4%	-3	-22%	-19	81	66
Lancaster County Resource Recovery	PA	231.02	180	-28%	-64	-42%	-96	167	135
Lancaster County Resource Recovery	PA	232.04	180	-28%	-64	-42%	-97	168	135
Lancaster County Resource Recovery	PA	233.49	180	-28%	-65	-42%	-97	169	136
Wheelabrator Falls	PA	430.12	150	-13%	-57	-30%	-129	373	301
Wheelabrator Falls	PA	451.76	150	-13%	-60	-30%	-136	392	316
York County Resource Recovery	PA	187.75	135	-4%	-7	-22%	-42	181	146
York County Resource Recovery	PA	206.45	135	-4%	-8	-22%	-46	199	161
York County Resource Recovery	PA	207.17	135	-4%	-8	-22%	-46	199	161

Facility Name	State	Projected 2023 NOx emissions (ton/yr)	Permit NOx limit (ppmvd)*	130 ppmvd control level estimated NOx reduction (%)	130 ppmvd control level estimated NOx reduction (ton/yr)	105 ppmvd estimated control level NOx reduction (%)	105 ppmvd control level NOx estimated reduction (ton/yr)	2023 projected NOx (ton/yr) at 130 ppmvd	2023 projected NOx (ton/yr) at 105 ppmvd
Covanta Alexandria/Arlington Energy	VA	75	110	130 ppmvd is higher than permit		-5%	-3	75	72
Covanta Alexandria/Arlington Energy	VA	77	110	130 ppmvd is higher than permit		-5%	-4	77	74
Covanta Alexandria/Arlington Energy	VA	75	110	130 ppmvd is higher than permit		-5%	-3	75	72
Covanta Fairfax Energy	VA	250	110	130 ppmvd is higher than permit		-5%	-11	250	239
Covanta Fairfax Energy	VA	250	110	130 ppmvd is higher than permit		-5%	-11	250	239

Facility Name	State	Projected 2023 NOx emissions (ton/yr)	Permit NOx limit (ppmvd)*	130 ppmvd control level estimated NOx reduction (%)	130 ppmvd control level estimated NOx reduction (ton/yr)	105 ppmvd estimated control level NOx reduction (%)	105 ppmvd control level NOx estimated reduction (ton/yr)	2023 projected NOx (ton/yr) at 130 ppmvd	2023 projected NOx (ton/yr) at 105 ppmvd
Covanta Fairfax Energy	VA	250	110	130 ppmvd is higher than permit		-5%	-11	250	239
Covanta Fairfax Energy	VA	250	110	130 ppmvd is higher than permit		-5%	-11	250	239
Total		22,992			(3,971)		(7,290)	19,021	15,702

* The majority of these limits reflect 7% O₂.

Appendix B: OTR Large MWC Characteristics

Plant Name	State	County	Manufacturer	Est Daily PTE (tons)	Amended Unit Type, based on part 60 classifications, ERC directory & permits	Tons MSW/day	Permit NOx Control
Covanta Bristol Energy	CT	Hartford	Zurn	0.332	Mass burn waterwall	358	SNCR
Covanta Bristol Energy	CT	Hartford	Zurn	0.414	Mass burn waterwall	358	SNCR
Covanta Southeastern Connecticut Company	CT	New London	Deutsche Babcock Anlagen	0.444	Mass burn waterwall	344.5	SNCR
Covanta Southeastern Connecticut Company	CT	New London	Deutsche Babcock Anlagen	0.444	Mass burn waterwall	344.5	SNCR
CT Resource Rec Authority Facility	CT	Hartford	CE	0.981	Refuse-derived fuel combustor	675.6 RDF; 236.4 coal	SNCR
CT Resource Rec Authority Facility	CT	Hartford	CE	0.981	Refuse-derived fuel combustor	675.6 RDF; 236.4 coal	SNCR
CT Resource Rec Authority Facility	CT	Hartford	CE	0.981	Refuse-derived fuel combustor	675.6 RDF; 236.4 coal	SNCR
Wheelabrator Bridgeport	CT	Fairfield	B&W	1.005	Mass burn waterwall	750	SNCR
Wheelabrator Bridgeport	CT	Fairfield	B&W	1.005	Mass burn waterwall	750	SNCR
Wheelabrator Bridgeport	CT	Fairfield	B&W	1.005	Mass burn waterwall	750	SNCR
Wheelabrator Lisbon	CT	New London	B&W	0.377	Mass burn waterwall	281.4	SNCR
Wheelabrator Lisbon	CT	New London	B&W	0.377	Mass burn waterwall	281.4	SNCR

Plant Name	State	County	Manufacturer	Est Daily PTE (tons)	Amended Unit Type, based on part 60 classifications, ERC directory & permits	Tons MSW/day	Permit NOx Control
Covanta Haverhill	MA	Essex	Ogden Martin	1.180	Mass burn waterwall	825	SNCR
Covanta Haverhill	MA	Essex	Ogden Martin	1.180	Mass burn waterwall	825	SNCR
SEMASS Resource Recovery	MA	Plymouth	Riley Stoker	1.190	Refuse-derived fuel combustor	995	
SEMASS Resource Recovery	MA	Plymouth	Riley Stoker	1.190	Refuse-derived fuel combustor	995	
SEMASS Resource Recovery	MA	Plymouth	Riley Stoker	1.129	Refuse-derived fuel combustor	995	SNCR
Wheelabrator Millbury Facility	MA	Worcester	B&W	0.999	Mass burn waterwall	864	SNCR
Wheelabrator Millbury Facility	MA	Worcester	B&W	0.999	Mass burn waterwall	864	SNCR
Wheelabrator North Andover	MA	Essex	Riley Stoker	0.892	Mass burn waterwall	750	SNCR
Wheelabrator North Andover	MA	Essex	Riley Stoker	0.892	Mass burn waterwall	750	SNCR
Wheelabrator Saugus	MA	Essex	Von Roll	1.005	Mass burn waterwall	750	SNCR
Wheelabrator Saugus	MA	Essex	Von Roll	1.005	Mass burn waterwall	750	SNCR
Montgomery County Resource Recovery	MD	Montgomery	Martin	0.794	Mass burn waterwall	600	LoNOx Mod & SNCR
Montgomery County Resource Recovery	MD	Montgomery	Martin	0.794	Mass burn waterwall	600	LoNOx Mod & SNCR
Montgomery County Resource Recovery	MD	Montgomery	Martin	0.794	Mass burn waterwall	600	LoNOx Mod & SNCR
Wheelabrator Baltimore Refuse	MD	Baltimore City	Wheelabrator Frye	1.005	Mass burn waterwall	750	SNCR - Optimized
Wheelabrator Baltimore Refuse	MD	Baltimore City	Wheelabrator Frye	1.005	Mass burn waterwall	750	SNCR - Optimized

Plant Name	State	County	Manufacturer	Est Daily PTE (tons)	Amended Unit Type, based on part 60 classifications, ERC directory & permits	Tons MSW/day	Permit NOx Control
Wheelabrator Baltimore Refuse	MD	Baltimore City	Wheelabrator Frye	1.005	Mass burn waterwall	750	SNCR - Optimized
Penobscot Energy Recovery	ME	Penobscot		0.854	Refuse-derived fuel combustor	360.5	
Penobscot Energy Recovery	ME	Penobscot		0.854	Refuse-derived fuel combustor	360.5	
Comaine	ME	Cumberland	Steinmüller	0.453	Mass burn waterwall	275	SNCR
Regional Waste Systems	ME	Cumberland	Steinmüller	0.453	Mass burn waterwall	275	SNCR
Wheelabrator Concord Facility	NH	Merrimack	B&W	0.456	Mass burn waterwall	287.5	SNCR
Wheelabrator Concord Facility	NH	Merrimack	B&W	0.456	Mass burn waterwall	287.5	SNCR
Camden Resource Recovery Facility	NJ	Camden		0.478	Mass burn waterwall	350	SNCR
Camden Resource Recovery Facility	NJ	Camden		0.478	Mass burn waterwall	350	SNCR
Camden Resource Recovery Facility	NJ	Camden		0.478	Mass burn waterwall	350	SNCR
Covanta Essex Company	NJ	Essex	Foster Wheeler	1.308	Mass burn waterwall	933	SNCR and Low NOx
Covanta Essex Company	NJ	Essex	Foster Wheeler	1.308	Mass burn waterwall	933	SNCR and Low NOx
Covanta Essex Company	NJ	Essex	Foster Wheeler	1.308	Mass burn waterwall	933	SNCR and Low NOx
Union County Resource Recovery	NJ	Union		0.667	Mass burn waterwall	480	SNCR and Low NOx
Union County Resource Recovery	NJ	Union		0.667	Mass burn waterwall	480	SNCR and Low NOx

Plant Name	State	County	Manufacturer	Est Daily PTE (tons)	Amended Unit Type, based on part 60 classifications, ERC directory & permits	Tons MSW/day	Permit NOx Control
Union County Resource Recovery	NJ	Union		0.667	Mass burn waterwall	480	SNCR and Low NOx
Wheelabrator Gloucester LP	NJ	Gloucester		0.334	Mass burn waterwall	287.5	SNCR
Wheelabrator Gloucester LP	NJ	Gloucester		0.334	Mass burn waterwall	287.5	SNCR
Covanta Babylon Inc	NY	Suffolk		0.453	Mass burn waterwall	375	SNCR
Covanta Babylon Inc	NY	Suffolk		0.453	Mass burn waterwall	375	SNCR
Covanta Hempstead	NY	Nassau	Deutsche Babcock Anlagen	1.748	Mass burn waterwall	890	SNCR
Covanta Hempstead	NY	Nassau	Deutsche Babcock Anlagen	1.748	Mass burn waterwall	890	SNCR
Covanta Hempstead	NY	Nassau	Deutsche Babcock Anlagen	1.748	Mass burn waterwall	890	SNCR
Covanta Niagara I, LLC	NY	Niagara	Deutsche Babcock Anlagen	1.683	Mass burn waterwall	1125	SNCR
Covanta Niagara I, LLC	NY	Niagara	Deutsche Babcock Anlagen	1.683	Mass burn waterwall	1125	SNCR
Huntington Resource Recovery	NY	Suffolk			Mass burn waterwall	250	SNCR
Huntington Resource Recovery	NY	Suffolk			Mass burn waterwall	250	SNCR
Huntington Resource Recovery	NY	Suffolk			Mass burn waterwall	250	SNCR

Plant Name	State	County	Manufacturer	Est Daily PTE (tons)	Amended Unit Type, based on part 60 classifications, ERC directory & permits	Tons MSW/day	Permit NOx Control
Onondaga County Resource Recovery	NY	Onondaga		0.680	Mass burn waterwall	330	SNCR
Onondaga County Resource Recovery	NY	Onondaga		0.680	Mass burn waterwall	330	SNCR
Onondaga County Resource Recovery	NY	Onondaga		0.680	Mass burn waterwall	330	SNCR
Wheelabrator Hudson Falls	NY	Washington			Mass burn waterwall	275	
Wheelabrator Hudson Falls	NY	Washington			Mass burn waterwall	275	
Wheelabrator Westchester	NY	Westchester		1.233	Mass burn waterwall	750	SNCR
Wheelabrator Westchester	NY	Westchester		1.233	Mass burn waterwall	750	SNCR
Wheelabrator Westchester	NY	Westchester		1.233	Mass burn waterwall	750	SNCR
Covanta Delaware Valley	PA	Delaware		0.665	Mass burn rotary waterwall		
Covanta Delaware Valley	PA	Delaware		0.665	Mass burn rotary waterwall		
Covanta Delaware Valley	PA	Delaware		0.665	Mass burn rotary waterwall		
Covanta Delaware Valley	PA	Delaware		0.665	Mass burn rotary waterwall		
Covanta Delaware Valley	PA	Delaware		0.665	Mass burn rotary waterwall		
Covanta Delaware Valley	PA	Delaware		0.665	Mass burn rotary waterwall		
Covanta Plymouth Renewable Energy	PA	Montgomery		0.965	Mass burn waterwall	608	

Plant Name	State	County	Manufacturer	Est Daily PTE (tons)	Amended Unit Type, based on part 60 classifications, ERC directory & permits	Tons MSW/day	Permit NOx Control
Covanta Plymouth Renewable Energy	PA	Montgomery		0.965	Mass burn waterwall	608	
Harrisburg Facility	PA	Dauphin		0.322	Mass burn waterwall	266	SNCR
Harrisburg Facility	PA	Dauphin		0.322	Mass burn waterwall	266	SNCR
Harrisburg Facility	PA	Dauphin		0.322	Mass burn waterwall	266	SNCR
Lancaster County Resource Recovery	PA	Lancaster		0.619	Mass burn waterwall	400	
Lancaster County Resource Recovery	PA	Lancaster		0.619	Mass burn waterwall	400	
Lancaster County Resource Recovery	PA	Lancaster		0.619	Mass burn waterwall	400	
Wheelabrator Falls	PA	Bucks		1.005	Mass burn waterwall	800	SNCR
Wheelabrator Falls	PA	Bucks		1.005	Mass burn waterwall	800	SNCR
York County Resource Recovery	PA	York	Deltak Blr w/O'Connor Rot Comb	0.468	Mass burn waterwall	449	
York County Resource Recovery	PA	York	Deltak Blr w/O'Connor Rot Comb	0.468	Mass burn waterwall	449	
York County Resource Recovery	PA	York	Deltak Blr w/O'Connor Rot Comb	0.468	Mass burn waterwall	449	
Covanta Alexandria/Arlington Energy	VA	Alexandria City	Keeler/Dorr-Oliver	0.276	Mass burn waterwall	325	
Covanta Alexandria/Arlington Energy	VA	Alexandria City	Keeler/Dorr-Oliver	0.276	Mass burn waterwall	325	

Plant Name	State	County	Manufacturer	Est Daily PTE (tons)	Amended Unit Type, based on part 60 classifications, ERC directory & permits	Tons MSW/day	Permit NOx Control
Covanta Alexandria/Arlington Energy	VA	Alexandria City	Keeler/Dorr-Oliver	0.276	Mass burn waterwall	325	
Covanta Fairfax Energy	VA	Fairfax	Ogden Martin	0.780	Mass burn waterwall	750	SNCR
Covanta Fairfax Energy	VA	Fairfax	Ogden Martin	0.780	Mass burn waterwall	750	SNCR
Covanta Fairfax Energy	VA	Fairfax	Ogden Martin	0.780		750	SNCR
Covanta Fairfax Energy	VA	Fairfax	Ogden Martin	0.780		750	SNCR

Appendix C: OTR Small MWCs

Plant Name	State	Permit NOx Limit ppmvd (24-hour limit)	Unit Type (Part 60 classifications)	Tons MSW/day	2023 Projected NOx Emissions (ton/yr)
Pioneer Valley Resource Recovery	MA	167	Modular Excess Air	136	40.91
Pioneer Valley Resource Recovery	MA	167	Modular Excess Air	136	45.41
Pioneer Valley Resource Recovery	MA	167	Modular Excess Air	136	40.51
Pittsfield Resource Recovery Facility	MA	192	Modular Excess Air	120	17.9
Pittsfield Resource Recovery Facility	MA	192	Modular Excess Air	120	18.8
Pittsfield Resource Recovery Facility	MA	192	Modular Excess Air	120	18.97
MMWAC Resource Recovery Facility	ME	315	Mass burn rotary waterwall*	125	211.28
MMWAC Resource Recovery Facility	ME	315	Mass burn rotary waterwall*	125	202.71
Dutchess Cnty Resource Recovery Facility	NY	170	Mass burn rotary waterwall	228	Missing
Dutchess Cnty Resource Recovery Facility	NY	170	Mass burn rotary waterwall	228	Missing
MacArthur Waste to Energy Facility	NY	170	Mass burn rotary waterwall	242.5	Missing
MacArthur Waste to Energy Facility	NY	170	Mass burn rotary waterwall	242.5	Missing
Oswego County Energy Recovery	NY		Modular starved air	50	199.79

Appendix D: Non-OTR MWC

State	Configuration	Rating (tons/day)	NOx Control	Permit NOx Limit 1*	Est NOx Rate*** (lb/MMBTU)
CA	Mass burn waterwall	400	Ammonia Injection	165	0.2835
CA	Mass burn waterwall	400	Ammonia Injection	165	0.2835
CA	Mass burn waterwall w/reciprocating grate		SNCR	205	0.3522
CA	Mass burn waterwall w/reciprocating grate		SNCR	205	0.3522
CA	Mass burn waterwall w/reciprocating grate		SNCR	205	0.3522
FL	Mass burn rotary waterwall	255		170	0.2921
FL	Mass burn rotary waterwall	255		170	0.2921
FL	Mass burn waterwall	250	SNCR	205	0.3522
FL	Mass burn waterwall	250	SNCR	205	0.3522
FL	Mass burn waterwall	460	SNCR	205	0.3522
FL	Mass burn waterwall	460	SNCR	205	0.3522
FL	Mass burn waterwall	460	SNCR	205	0.3522
FL	Mass burn waterwall	690	Covanta LN™, SNCR, FGR	110	0.1890
FL	Mass burn waterwall	660	SNCR	180	0.3093

State	Configuration	Rating (tons/day)	NOx Control	Permit NOx Limit 1*	Est NOx Rate*** (lb/MMBTU)
FL	Mass burn waterwall	660	SNCR	180	0.3093
FL	Mass burn waterwall	660	SNCR & FGR	150	0.2577
FL	Mass burn waterwall	288	SNCR	205	0.3522
FL	Mass burn waterwall	288	SNCR	205	0.3522
FL	Mass burn waterwall	288	SNCR	205	0.3522
FL	Mass burn waterwall	288	SNCR	205	0.3522
FL	RDF Spreader Stoker	648	SNCR	250	0.4295
FL	RDF Spreader Stoker	648	SNCR	250	0.4295
FL	RDF Spreader Stoker	648	SNCR	250	0.4295
FL	RDF Spreader Stoker	648	SNCR	250	0.4295
FL	RDF	900	SNCR	250	0.4295
FL	RDF	900	SNCR	250	0.4295
FL	Stoker Mass Burn waterwall	1000	SCR	50	0.0859
FL	Stoker Mass Burn waterwall	1000	SCR	50	0.0859
FL	Stoker Mass Burn waterwall	1000	SCR	50	0.0859
FL	Mass burn waterwall	350	SNCR	205	0.3522
FL	Mass burn waterwall	350	SNCR	205	0.3522

State	Configuration	Rating (tons/day)	NOx Control	Permit NOx Limit 1*	Est NOx Rate*** (lb/MMBTU)
FL	Mass burn waterwall	350	SNCR	205	0.3522
FL	Mass burn waterwall	1050	SNCR	205	0.3522
FL	Mass burn waterwall	1050	SNCR	205	0.3522
FL	Mass burn waterwall	1050	SNCR	205	0.3522
FL	Mass burn waterwall	836	SNCR	205	0.3522
FL	Mass burn waterwall	836	SNCR	205	0.3522
FL	Mass burn waterwall	836	SNCR	205	0.3522
IN	Mass burn waterwall	726	SNCR	205	0.3522
IN	Mass burn waterwall	726	SNCR	205	0.3522
IN	Mass burn waterwall	726	SNCR	205	0.3522
MI	Mass burn waterwall	312.5	SNCR	205	0.3522
MI	Mass burn waterwall	312.5	SNCR	205	0.3522
MN	Mass burn waterwall	606	Ammonia Injection	205	0.3522
MN	Mass burn waterwall	606	Ammonia Injection	205	0.3522
MN	Stoker mass burn waterwall	100		500	0.8590
MN	Stoker mass burn waterwall	200	SNCR	150	0.2577
MN	Stoker mass burn waterwall	100		500	0.8590

State	Configuration	Rating (tons/day)	NOx Control	Permit NOx Limit 1*	Est NOx Rate*** (lb/MMBTU)
MN	Starved air modular	48		500	0.8590
MN	Starved air modular	48		500	0.8590
MN	RDF air swept, traveling grate	393.6		250	0.4295
MN	RDF air swept, traveling grate	393.6		250	0.4295
OK	Mass burn waterwall	375	SNCR	205	0.3522
OK	Mass burn waterwall	375	SNCR	205	0.3522
OK	Mass burn waterwall	375	SNCR & Tertiary Air	205	0.3522
OR	Mass burn waterwall	275	SNCR	200	0.3436
OR	Mass burn waterwall	275	SNCR	200	0.3436
VA	RDF Spreader Stoker	593		250	0.4295
VA	RDF Spreader Stoker	593		250	0.4295
VA	RDF Spreader Stoker	593		250	0.4295
VA	RDF Spreader Stoker	593		250	0.4295
WA**	Mass burn waterwall	475		165	0.2835
WA**	Mass burn waterwall	475		165	0.2835

* ppmvd @12% CO₂.

** 8-hour average, all others are 24-hour average.

*** From permit NOx rate and EPA Method 19.

Appendix E: Conversion of NOx Concentration to Mass

Below is an example of the calculation for conversion of NOx from concentration in ppm to lb/MMBtu and then ultimately from lb/MMBtu to lb/hr.

9.3 OTHER CEMS/CERMS CALCULATIONS

9.3.1 Calculation of Emissions in lb/MMBtu

Pollutant emission in units of lb/MMBtu are calculated as follows (see 40 CFR 60 Appendix A, Reference Method 19):

$$E = C_d * R * F_d * \left[\frac{20.9}{(20.9 - \%O_{2d})} \right]$$

Where:

- E = Pollutant emission rate in pounds of pollutant per million Btu (lb/MMBtu).
- C_d = Average pollutant concentration (ppm SO₂, NO_x or CO) recorded by the CEM Data Logger Subsystem, dry and calibration corrected, for a given hour.
- R = Conversion factor - ppm to lb/scf (SO₂ = 1.660E⁻⁷, NO_x = 1.194E⁻⁷, CO = 7.267E⁻⁸).
- F_d = O₂ based F-factor (9570 dscf/MMBtu).
- %O_{2d} = Average diluent concentration (% O₂) recorded by the CEM data logger subsystem, for a given hour, dry and calibration corrected.

In addition to the above example, more detail on the conversion calculations are provided below. In this example, an MWC with a NOx concentration emission limit of 150 ppm, and design capacity of 382 MMBtu/hr is used.:

$$\text{lb/MMBtu} = (1.37 * 10^{-6} / 460 + T_s) * \text{MWp} * \text{F-factor} / \text{MMBtu} * 20.9 / (20.9 - \% \text{Oxygen}) * (\text{ppm})$$

Where T_s = 68: T_s = stack gas T

MWp = Molecular weight (of NOx)

MWp NOx = 46

F-factor/MMBtu = 9570 for municipal solid waste in Appendix A EPA test method 19

%Oxygen = 7

$0.00000137/528 \times 46 \times 9570 \times (20.9/13.9) \times 150 = 0.257 \text{ lb/MMBtu}$

$0.257 \text{ lb/MMBtu} \times 382 \text{ MMBtu/hr} = 98.2 \text{ lb/hr NOx}$

$98.2 \text{ lb/hr} \times 24 \text{ hr/day} \times 1 \text{ ton}/2,000 \text{ lb} = 1.2 \text{ tons per day (tons per summer day)}$

Ts = stack gas T

T2 = standard T (32F)

1 mole = 22.4 L

$\text{ug}/\text{m}^3 = (\text{moles of pollutant}/10^6 \text{ moles}) \times (460+T2)/(460+Ts)$

$\text{ug}/\text{m}^3 = 44.64 \times \text{MWp} \times (460+T2)/(460+Ts)$ for 1 ppm

$\text{ug}/\text{m}^3 = (21,962.88 \times \text{MWp})/(460+Ts) \times (\text{ppm})$ for more than 1 ppm

$\text{lb}/\text{ft}^3 = (21,962.88/460+Ts) \times \text{MWp} \times (\text{m}^3/35.31\text{ft}^3) \times (\text{g}/10^6 \text{ ug}) \times (\text{lb}/454 \text{ g})$ for 1 ppm

$\text{lb}/\text{ft}^3 = 1.37 \times 10^{-6} \times \text{MWp}/(460+Ts) \times (\text{ppm})$ for more than 1 ppm

Td = default T = 68 degrees F

Rankin scale where (degrees F + 460 = degrees Rankin) which is used in thermodynamics

$\text{lb}/\text{MMBtu} = (1.37 \times 10^{-6}/460+Td) \times \text{MWp} \times \text{F-factor}/\text{MMBtu} \times 20.9/(20.9-\% \text{Oxygen})$ for 1 ppm

$\text{lb}/\text{MMBtu} = (1.37 \times 10^{-6}/460+Ts) \times \text{MWp} \times \text{F-factor}/\text{MMBtu} \times 20.9/(20.9-\% \text{Oxygen}) \times (\text{ppm})$ for more than 1 ppm

Appendix F: MWC Technology Descriptions

Municipal waste combustors are intended to reduce the volume of municipal solid waste through combustion of that solid waste. Municipal solid waste is a fuel that tends to be a heterogeneous mixture of heavy and light materials of various combustibility. Most MWCs are designed to recover some of the heat generated from the MSW combustion process through heat absorption by radiant and convective water-cooled and steam-cooled tubing surfaces. MWCs may incorporate the steam generator within the MWC as an integral component, or the steam generator is a separate entity acting as a waste heat recovery device attached to the MWC. There are many designs and configurations of MWC units, often depending upon the intended volume of MSW throughput, characteristics of the design “municipal waste fuel”, and the experience and preferences of the owner/operator and engineering/design organization.

The majority of the OTR MWCs can be generalized into three major categories based on their individual municipal solid waste combustion process characteristics. One type of MWC is often referred to as mass burn, where the MSW is combusted in an as-received condition with only the removal of large objects prior to its introduction to the MWC. Most mass burn MWCs are essentially steam generators with MSW as the primary fuel.

The second type of MWC utilizes refuse derived fuel (RDF), a type of municipal solid waste produced by processing municipal solid waste through shredding and size classification to produce low-density fluff RDF (in the OTR), densified RDF or pelletized RDF. The majority of RDF MWCs are essentially steam generators using RDF as the primary fuel.

The third type of MWC is sometimes referred to as a modular MWCs. These units are mass burn (unprepared MSW, other than removal of large objects). However, modular MWCs are generally smaller units that are shop-built rather than field-erected and utilize two combustion chambers. There are generally two types of modular controlled air MWCs, one that utilizes sub-stoichiometric air combustion conditions in the primary chamber (modular starved air MWC) and the other that utilizes excess air combustion conditions in the primary chamber (modular excess air MWC). This type of MWC generally features a secondary combustion chamber with supplemental fuel burners and combustion air supply. The modular MWC combustor does not generally incorporate heat recovery in the combustion chambers themselves, but in many cases the flue gases from the modular MWC are exhausted to a heat recovery steam generator for energy recovery.

Mass Burn MWCs

In the OTR, there are two major sub-categories of mass burn MWCs: mass burn waterwall MWCs and rotary waterwall MWCs.

- Mass Burn Waterwall MWCs

Mass burn waterwall MWCs have lower furnace primary combustion zones made of waterwall tubes for heat transfer in the combustion zone. For mass burn water wall MWCs, the MSW fuel is typically loaded into charging hoppers and fed to hydraulic rams that push the MSW fuel onto the stoker grate in the furnace for combustion. Most stokers utilize a reciprocating grate action, utilizing either forward or reverse acting grate movement, that moves the combusting MSW fuel across the furnace to allow time for drying and complete combustion. Generally, there will be a large volume of fuel at the front end of the grate that burns down to a small amount of ash at the back of the grate. The grate may have a slightly downward angle from fuel introduction to the ash drop off to help move the MSW fuel through the furnace. The reciprocating action of the grates also tends agitate the MSW fuel, generally causing the MSW fuel to roll and mix. This agitation helps ensure all of the MSW fuel is exposed to the high temperatures in the bed of combusting MSW fuel and helps provide contact with combustion air, resulting in more complete combustion of the MSW fuel as it travels across the furnace. Combustion ash that does not leave the stoker grate as fly ash is dropped off at the end of the stoker through a discharge chute for disposal or further processing.

Mass burn waterwall MWCs may also incorporate auxiliary fuel burners to help bring the MWCs to temperature to begin combustion of the MSW fuel, to supplement the heat input necessary to attain the steam generator output rating with varying MSW fuel quality, or to ensure sufficient flue gas temperatures are attained for proper emissions control.

Combustion air is generally introduced to the combustion zone utilizing pressurized air as underfire (primary) air or overfire (secondary) air. At least one proprietary design, however, splits the overfire air into two distinct zones, effectively creating three combustion air introduction zones.

Underfire air is introduced under the stoker grate, sometimes through a series of plenums that allow for the amount of underfire air introduced to various portions of the grate area to be controlled to enhance combustion based on MSW fuel characteristics. The underfire air travels from the plenums to the combustion zone through holes in the grate to assure good distribution across the grate. Underfire air systems are generally designed to be able to provide up to 70% of the total combustion air requirement, with typical underfire air operating requirements utilizing 50% to 60% of the total combustion air.

Overfire air is introduced into the furnace above the grate level through multiple ports in the furnace walls. The primary purpose of the overfire air is to provide the amount of air necessary to mix the furnace gasses leaving the grate combustion zone and provide the oxygen required to complete the combustion process. Proper control of the overfire air may also be utilized to provide some control of

the NOx emission rate leaving the high temperature zone of the furnace. The amount of overfire air is typically 40% to 50% of the total required combustion air, and is somewhat dependent upon MSW fuel quality and NOx emission control requirements.

- **Rotary Waterwall MWCs**

A rotary waterwall MWC utilizes a water cooled, tilted, rotating cylindrical combustion chamber. The MSW fuel is typically loaded into charging hoppers and fed to hydraulic rams that push the MSW fuel into the slowly rotating combustion chamber. The rotation of the tilted cylindrical combustion chamber causes the MSW fuel to tumble and advance the length of the cylindrical combustion chamber, ensuring all of the MSW fuel is exposed to high temperatures and combustion air for a sufficient amount of time for drying and complete combustion of the MSW fuel. Combustion ash that does not leave the rotary burner as fly ash is dropped off at the end of the rotary burner through a discharge chute for disposal or further processing.

Rotary burner MWCs may also incorporate auxiliary fuel burners to help bring the MWCs to temperature to begin combustion of the MSW fuel, to supplement the heat input necessary to attain the steam generator output rating with varying MSW fuel quality, or to ensure sufficient flue gas temperatures are attained for proper emissions control.

Combustion air for rotary burner MWCs is introduced to the rotating combustion chamber by a pressurized plenum surrounding the rotating combustion chamber. The combustion air enters the rotating combustion chamber through the walls of the chamber, generally through spaces between waterwall tubes. Underfire air is introduced at the bottom of the rotating combustion chamber and through the bed of combusting MSW. Overfire air is introduced into the rotating combustion chamber over the bed of combusting MSW.

Dampers are utilized to proportion the total air flow and control the overfire air/underfire air split.

RDF MWCs

In contrast to mass burn MWCs, RDF MWCs employ a more complex feeder/spreader system and different combustion bed characteristics. The prepared RDF is ram fed to a feeder hopper, where a conveying device further mixes and fluffs the RDF into a more uniform density as it transports the RDF to fuel/air spreader spouts. Multiple fuel/air spreader spouts located across the furnace and above the stoker grate distribute the RDF evenly across the width of a traveling grate, while the air pressure may be continuously varied to help provide a more uniform fuel bed over the depth of the grate. The traveling grate typically travels from the rear of the furnace to the front in the direction of the fuel distribution. Combustion of the RDF takes place in suspension for the lower density fraction and on the stoker grate for the higher density fraction. The underfire combustion air passing through the traveling grate provides some agitation to the fuel bed to help ensure all the RDF is exposed to high temperatures and sufficient combustion air to ensure more complete combustion as it travels across the furnace. Like the mass burn combustion system, ash from the combustion process that does not leave the grate as fly ash will be dropped off at the end of the stoker through a discharge chute for disposal or further processing.

For RDF burning MWCs, combustion air is generally introduced to the combustion zone utilizing pressurized air as underfire (primary) air or overfire (secondary) air.

Underfire air (sometimes referred to as undergrate air) is introduced under the stoke grate. The underfire air is generally introduced into the steam generator through a single undergrate plenum and relies on enough pressure drop to supply combustion air evenly through all portions of the grate. Underfire air systems are generally designed to be able to provide up to 70% of the total combustion air requirement, with typical underfire air operating requirements utilizing 50% to 60% of the total combustion air.

Overfire air is introduced into the furnace above the grate level through multiple ports in the furnace walls. The primary purpose of the overfire air is to provide enough air to mix the furnace gasses leaving the grate combustion zone to provide the oxygen required to complete the combustion process. Proper control of the overfire air may provide some control of the NO_x emission rate leaving the high temperature zone of the furnace. The amount of overfire air is typically 40% to 50% of the total required combustion air, being somewhat dependent upon the RDF fuel quality and NO_x emission control requirements.

The fuel/air spreaders generally require approximately 5% of the total air flow requirement at any given load to properly distribute the RDF fuel in the furnace over the grate.

RDF MWCs may also incorporate auxiliary fuel burners to help bring the MWCs to temperature to begin combustion of the RDF, to supplement the heat input necessary to attain the steam generator output rating with varying RDF quality, or to ensure sufficient flue gas temperatures are attained for proper emissions control.

Modular MWCs

Modular MWCs are generally of smaller capacity than mass burn and RDF MWCs and utilize two combustion zones rather than one. The MSW fuel is typically introduced to the MWC without preparation other than removing large objects. MSW fuel is dropped into a chute and is pushed by rams into the first, or primary, combustion chamber and on to a reciprocating grate(s) or moving hearth. Instead of traveling grates or hearths, some modular MWCs may utilize a series of stepped rams to move the combusting MSW fuel across the combustion chamber. The MSW fuel is dried and combusted as it travels across the primary combustion chamber, and any ash not leaving the primary chamber as fly ash is dropped off at the end of the primary combustion chamber into a discharge chute for disposal or further processing.

The combustion zones of modular MWCs generally do not incorporate any heat recovery water or steam walls. Instead the combustion zones generally consist of refractory lined walls. Heat recovery, if any, occurs in a heat recovery steam generator that is connected to the exhaust of the secondary combustion chamber. The distribution of combustion air is the primary distinction between the designs of modular starved air MWCs and modular excess air MWCs.

Combustion air for modular starved air MWCs is proportioned to provide combustion air to the primary combustion chamber and to the secondary combustion zone, with the amount of air supplied to the primary combustion chamber controlled such that combustion in the primary chamber is sub-stoichiometric (i.e. less oxygen than is necessary to achieve complete combustion). This results in flue gases exiting the primary chamber with high levels of combustibles. The flue gases enter the secondary chamber, where additional air (secondary air) is injected to complete the combustion process. The relatively high amount of secondary air injection also provides a high amount of turbulence to ensure mixing with the combustible portions of the primary combustion chamber flue gases. One of the intended results of the primary chamber sub-stoichiometric combustion is reduced air/flue gas velocity causing less turbulence in the combustion bed, less flue gas particulate carried out from the primary chamber, and lower peak combustion temperatures. However, the modular starved air MWC may reasonably be expected to have higher levels of unburned fuel than other types of MWCs.

Combustion air for modular excess air MWCs is also proportioned between the primary and secondary combustion chambers, but the amount of combustion air supplied to the primary chamber is proportioned to provide combustion conditions at greater than stoichiometric conditions (i.e. more oxygen than is necessary to achieve complete combustion). This may lead to higher levels of particulate carry-out from the primary combustion chamber and a higher degree of MSW fuel burnout.

Modular air MWCs may also incorporate auxiliary fuel burners to help the MWC operate with varying MSW fuel characteristics or to ensure appropriate flue gas temperatures are attained for proper emissions control.

MWC Retrofit NOx Control Technologies

MWCs are intended to combust a municipal waste fuel that tends to be a heterogeneous mixture of heavy and light materials of variable combustibility. Both fuel and thermal NOx is generated by the combustion process, with some limited degree of control possible through variation of the primary/secondary air ratio. The variation in MWC unit design and fuel quality leads to a range of expected uncontrolled NOx emissions, sometimes given as a range of 250 ppmvd @7% O₂ to 300 ppmvd @7% O₂. There are several NOx control options that can be retrofitted to existing MWCs, with applicability and effectiveness dependent upon unit configuration. Not all NOx reduction technologies are applicable to all MWC configurations, and not all technologies are reasonably feasible from an economic standpoint even if they are technologically feasible. Assessments of individual MWCs are necessary to evaluate the technical and economic feasibility of any NOx reduction technology for that MWC. However, the following information provides a limited indication of general applicability and cost effectiveness of various control equipment types.

Combustion Air Control

For the purposes of this document, combustion air control technology for NOx control on MWCs means utilization of low excess air operation or staged combustion, either separately or in combination. For low excess air operation, the overall amount of combustion air in the system is

reduced generally through reduction of both underfire and overfire air. For staged combustion, the amount of underfire air is reduced to reduce the air available during the initial stages of combustion, while the amount of overfire air is increased to provide enough air to complete the combustion process. The generally high excess air requirements needed to achieve complete combustion of the non-homogenous MSW fuel provides only limited ability to attain NO_x reductions through excess air reduction while still maintaining acceptable MSW fuel burnout, although some NO_x rate reduction may be possible at some MWCs. By design, the majority of MWCs incorporate some level of control to proportion underfire and overfire air to optimize combustion quality with NO_x generation rate so this technology is more of an operational tuning control technology. Industry information indicates that combustion air optimization for NO_x control has the potential to reduce NO_x emission rates by up to 10% while still maintaining acceptable fuel burnout on many MWCs. Because this “technology” control is already part of most OTR MWCs, it is assumed that optimizing combustion air control is already part of good operating practices.

Selective Non-Catalytic Reduction

Selective non-catalytic reduction (SNCR) is a retrofit-capable NO_x control technology that is widely utilized for existing MWC units, including those located in the OTR. For SNCR, reagents (urea or ammonia) are injected into the MWC furnace at locations in the proper temperature range to drive chemical reactions between the reagents and NO_x, resulting in the nitrogen in NO_x being reduced to elemental nitrogen (N₂) and water vapor. SNCR systems generally include reagent storage facilities, supply of demineralized water, electric power supply, pumps, mixing components, a heated structure to protect the pump skid and mixing/flow control components from colder ambient temperatures, pressurized air supply, pipes and tubing, flow control valves, a control system, communication with steam generator control and instrumentation systems, and penetrations into the steam generator at the proper locations to install SNCR injection nozzles. The effectiveness of NO_x control using SNCR will be a function of the MWC’s characteristics (such as furnace configuration, combustion excess air requirements, flue gas temperature gradients, etc.) to attain the proper orientation and location of SNCR injector nozzles and the ability to achieve proper reagent atomization and sufficient time for reagent contact and mixing with the flue gas in the proper temperature range. SNCR effectiveness will also be affected by the ability to consistently introduce the appropriate amount of reagents across the MWC’s load range and in reaction to changes in MSW fuel characteristics. Literature suggests that SNCR is a technologically feasible NO_x control system applicable to many MWCs.

The use of properly designed and well-tuned SNCR technology has been demonstrated to achieve approximate 40% to 50% reductions in NO_x emission rates with low ammonia slip values at many facilities, including retrofit applications. Compliance with 150 ppmvd @7% O₂ 24-hr average NO_x emission rate limitations has been demonstrated at many OTR MWC facilities utilizing SNCR as the primary NO_x control.

Some historic non-OTR NO_x RACT evaluations and cost effectiveness estimates have been identified in EPA’s RACT/BACT/LAER Clearinghouse regarding the use of SNCR on MWC units. Two are described below.

- The Lee County Waste to Energy facility (Florida) indicated an estimated cost effectiveness of \$2,000/ton (approximately \$2,880/ton in 2020 dollars) of NO_x reduced utilizing SNCR for control on a 660 ton/day MWC. The permit NO_x rate limits were 110 ppmvd 12-month average and 150 ppmvd 24-hour average.
- The Hillsborough County Resource Recovery facility (Florida) indicated an estimated cost effectiveness of \$1,000/ton (approximately \$1,500/ton in 2020 dollars) of NO_x reduced utilizing SNCR for control on a 600 ton/day MWC. The permit NO_x rate limits were 90 ppmvd 12-month average and 110 ppmvd 24-hour average.

Some historic industry information suggests a very wide range of NO_x reduction cost effectiveness values as a function of the size (input capacity) of MWCs. This information suggests that estimated cost effectiveness values may range from approximately \$7,400/ton for small MWCs (100 ton/day and smaller) to approximately \$1,900/ton for large MWCs (750 ton/day and larger), based on a 50% NO_x reduction and 80% annual capacity factor. Variations in capacity factor, required level of NO_x reduction, and other factors would shift the estimated cost effectiveness range. As portions of SNCR can be shared among multiple MWCs at a single facility (reagent preparation, reagent storage, demineralized water supply, pumping/forwarding skids, etc.), the per MWC NO_x reduction estimated cost at a multi-MWC facility may be lower.

Flue Gas Recirculation

Flue gas recirculation (FGR) technology can be a stand-alone NO_x reduction technology, but as SNCR is already being utilized for many OTR MWCs, for this discussion it will be assumed that a retrofit FGR system would be utilized in combination with the continued use of existing SNCR technology. The equipment and function of the existing SNCR portion of this option is assumed to be unchanged from that of properly tuned existing SNCR technology.

FGR helps reduce NO_x emission rates by slightly reducing the average oxygen content in the combustion zone and also by reducing the peak temperatures in the combustion zone. An FGR retrofit would generally require the installation new ductwork, fan, control dampers and damper operators, electric power supply, flue gas injection/mixing nozzles, system controls, and integration with the steam generator controls and instrumentation. Retrofit FGR would generally be designed to extract a portion of the flue gases from ductwork downstream of the steam generator convective passes. Utilizing a fan, the extracted flue gases would be mixed with the secondary air prior to introduction into the combustion zone. As indicated above, by diluting the secondary air with the flue gases, the average amount of excess air available for combustion and average flame temperature are reduced resulting in lower levels of NO_x formation. The amount of gas recirculated would be controlled to ensure complete combustion of the MSW fuel.

FGR is listed as an installed equipment at a couple of MWC facilities in the OTR. FGR is potentially a technically feasible retrofit technology for many MWCs. An exception might be a modular MWC not incorporating any heat recovery as that would hamper the ability to reduce flue gas temperatures to a range useful for recirculation to the combustion zone.

Babcock Power Environmental prepared an analysis for potential installation of FGR-SNCR at the Wheelabrator Baltimore MWC facility, which includes three MWCs each with a rating of 625 ton/day. The evaluation predicted the ability to maintain a 120 ppmvd @7% O₂ 24-hr NO_x rate limit and a 115 ppmvd @7% O₂ 30-day NO_x rate limit with ammonia slip of approximately 5 ppmvd.

A cost effectiveness estimate was performed using the data provided in the Babcock Power document. Using the cost assumptions for this particular facility (as discussed in the Babcock Power document with a 20-year control life with 6% interest rate), the incremental cost effectiveness was estimated at \$3,470/ton of NO_x reduced. There could be a significant range in estimated cost effectiveness due to MWC input capacity (and the need for the corresponding difference in amount of recirculated gas). For similar types of MWCs, the range of sizes would require the same level of engineering and design, and the same type of components (potentially varying in size), therefore many of the associated costs are similar. Because the ton/year of NO_x mass reduction would vary with the input range of the MWCs, this could lead to a large range in the estimated cost effectiveness. Using the Babcock and Wilcox Wheelabrator Baltimore evaluation as a base input, the estimated FGR cost effectiveness could range from approximately \$3,200/ton to \$11,000/ton.

Advanced SNCR

Advanced SNCR (ASNCR) NO_x control technology may be considered for retrofit on existing MWCs as either a new retrofit technology or a significant upgrade to an existing SNCR. ASNCR is like SNCR in that it utilizes the injection of reagents into the proper temperature zones of the furnace to reduce the flue gas NO_x concentration. Both SNCR and ASNCR designs may utilize advanced computer modeling techniques to specify SNCR nozzle locations and elevations so that their operation may be optimized across varying furnace conditions. The primary difference between a well-designed SNCR and ASNCR system is that ASNCR would utilize advanced furnace temperature monitoring instrumentation to provide near real time operating furnace temperature profiles. This information allows the control system to modulate which ASNCR injectors are in operation and to automatically adjust the individual injector flow rate in order to optimize the overall NO_x emission rate. This advanced system optimizes the NO_x reduction chemical reaction across the furnace to achieve high levels of overall NO_x reduction while maintaining low ammonia slip. Babcock and Wilcox (B&W) prepared an analysis for the Wheelabrator Baltimore facility that included the potential use of ASNCR technology for NO_x control. The B&W information suggests that ASNCR may be applicable to many MWCs as a retrofit technology, although furnace configuration or other factors could affect the NO_x reduction potential.

Babcock Power prepared an analysis for potential installation of ASNCR at the Wheelabrator Baltimore MWC facility. The evaluation predicted the ability to maintain a 110-125 ppmvd @7% O₂ 24-hr NO_x rate limit and a 105-110 ppmvd @7% O₂ 30-day NO_x rate limit with ammonia slip of approximately 5 ppmvd.

A cost effectiveness estimate was performed using the data provided in the Babcock Power document. Using the cost assumptions for this particular facility (as discussed in the Babcock Power document and assuming a 20-year control life with 6% interest rate), the incremental cost effectiveness was estimated at \$3,883/ton of NO_x reduced.

Some industry information indicates that while it is likely that most MWCs could successfully retrofit ASNCR and expect NOx reductions, its ability to achieve significant amounts of NOx reduction in small MWCs is limited due to the reduced space and contact time. These factors are influenced by individual unit design. An insufficient amount of information is available to provide an estimate of the range of cost effectiveness for small MWCs.

Another control option combines ASNCR with FGR. The equipment and function of the ASNCR portion of this option is identical to that of the ASNCR-only technology described above. The FGR part would be identical to the above FGR discussion, where a portion of the flue gases is extracted downstream of the convective passes of the steam generator and those flue gases are injected into the secondary air system using an FGR fan. By diluting the secondary air with flue gases, the average amount of excess air available for combustion is reduced and the average flame temperature is reduced, resulting in lower levels of NOx formation. The lower levels of NOx formed are further reduced by the reaction of the flue gas NOx with the ASNCR reagents, which are enhanced by the high flow rate of the secondary air and recirculated flue gas mixture.

Babcock Power Environmental prepared an analysis for potential installation of FGR-SNCR at the Wheelabrator Baltimore MWC facility. The evaluation predicted the ability to maintain a 105 ppmvd @7% O₂ 24-hr NOx rate limit and a 100 ppmvd @7% O₂ 30-day NOx rate limit with ammonia slip of approximately 5 ppmvd.

A cost effectiveness estimate was performed using the data provided in the Babcock Power document. Using the cost assumptions for this particular facility (as discussed in the Babcock Power document with a 20-year control life with 6% interest rate), the incremental cost effectiveness was estimated at \$4,695/ton of NOx reduced.

Covanta Proprietary Low-NOx

The Covanta Low-NOx (LNTM) is a proprietary NOx reduction technology. The LNTM process modifies the combustion process by diverting a portion of the secondary air and injecting it (tertiary air) at a higher elevation in the furnace. The distribution of combustion air between the primary, secondary, and tertiary levels is controlled to optimize combustion control and reduce NOx emissions by providing additional fuel/air staging for NOx control while still providing enough air for complete combustion. The installation of the LNTM system on a combustion unit already incorporating SNCR may require modifications to the SNCR system to optimize the combined NOx reduction effect of the LN and SNCR technologies. Covanta's website indicates that the propriety LNTM technology has already been installed on many of the MWCs operated by Covanta, with plans to install it on many more. The proprietary aspects of this technology suggest it is unlikely that it can be installed on non-Covanta MWCs.¹⁹

The Covanta LNTM technology was permitted as RACT for retrofit installation and operation in conjunction with SNCR at the Covanta Fairfax facility in Virginia. The permit NOx emission limits are 110 ppmvd @7% O₂ 24-hr, and 90 ppmvd @7% O₂ annual. Prior to the LNTM retrofit, the

¹⁹ See footnote 3 for reference.

facility's MWCs typically operated with NOx emission rate set-points ranging from 160 ppmvd to 180 ppmvd (dependent upon furnace conditions) in compliance with the permitted 205 ppmvd emission rate limits. Information provided in the RACT analysis for Covanta Fairfax indicated that at that time, the Covanta LNTM technology had been installed in approximately 20 units. The calculated incremental cost effectiveness for Covanta Fairfax was \$2,888/ton of NOx removed.

The Covanta LNTM technology was also permitted as RACT for retrofit installation and operation in conjunction with SNCR at the Covanta Alexandria/Arlington facility in Virginia. The permit NOx emission limits are 110 ppmvd @7% O₂ 24-hr, and 90 ppmvd @7% O₂ annually. Prior to LNTM retrofit, the facility's MWCs typically operated with NOx emission rate set-points ranging from 160 ppmvd to 180 ppmvd (dependent upon furnace conditions) in compliance with permitted 205 ppmvd emission rate limits. The calculated incremental cost effectiveness for Covanta Alexandria/Arlington was \$4,005/ton of NOx removed.

The proprietary Covanta LNTM technology with SNCR technology has been in operation on the Montgomery County Resource Recovery unit in Maryland for several years. A recent study was performed at the request of MDE to address the potential for any additional NOx rate reduction capability that could be considered RACT. The evaluation noted that the facility has been able to typically control its average 24-hour NOx rate to less than 100 ppm, but that there are some periodic spikes in excess of those values caused by process variations that are outside operator control. The document concludes that an emissions limitation of 140 ppmvd @7% O₂, 24-hr average, is reasonable and can be met with good ammonia slip control.²⁰

Covanta Bristol in Connecticut has incorporated the proprietary Covanta LNTM technology on one of its combustion units, and has been permitted with a 120 ppmvd @7% O₂ NOx, 24-hr average, emission rate limit.

Selective Catalytic Reduction

Selective catalytic reduction (SCR) is a retrofit-capable NOx reduction technology where ammonia is injected into the flue gases ahead of a catalyst. In the proper temperature range, the nitrogen in the flue gas NOx is reduced to elemental nitrogen by the catalyst. Incorporation of SCR on an existing unit requires installation of a catalyst module in the flue gas ductwork, the installation of an ammonia storage and injection piping and control system, instrumentation, and coordination with steam generator controls to ensure the appropriate amount of ammonia is injected into the flue gas ahead of the catalyst. Since the temperature of the flue gases downstream of the steam generator convective passes may be too low to enough chemical reaction in the catalyst, most MWC units also require a means of reheating the flue gas to acceptable levels. This could be accomplished through installation of burners or other heat exchangers in the ductwork ahead of the catalyst module. In some installations, it may also be necessary to upgrade the existing induced draft fan(s) to overcome the draft loss through the catalyst. While this

²⁰ See footnote 4.

technology is applicable and effective to most MWCs, the space availability and configuration of a given facility may make it infeasible. SCR is also very costly from a capital expense standpoint.

Babcock Power prepared an analysis for potential installation of SCR at the Wheelabrator Baltimore MWC facility. While the analysis did not provide a site-specific prediction for the achievable NO_x emission rate, the evaluation discussed BACT rates for a new MWC facility that incorporated SCR. The discussed NO_x emission rates were 50 ppmvd @7% O₂ 24-hr NO_x rate limit and 45 ppmvd @7% O₂ 30-day NO_x rate limit, with ammonia slip of approximately 10 ppmvd.

A cost effectiveness estimate was performed using the data provided in the Babcock Power document. Using the cost assumptions for the Wheelabrator Baltimore facility (as discussed in the Babcock Power document with a 20-year control life with 6% interest rate), the incremental cost effectiveness was estimated from \$10,296/ton to \$12,779/ton of NO_x reduced, depending upon which flue gas reheating mechanism was chosen.

The RACT evaluation for the Covanta Alexandria/Arlington facility addressed the potential for installing SCR at that site. This evaluation also cited the same new MWC facility SCR installation as Babcock Power did in their Wheelabrator Baltimore facility evaluation, along with the 50 ppmvd @7% O₂ 24-hr NO_x rate limit and 45 ppmvd @7% O₂ 30-day NO_x rate limit. The Covanta Alexandria/Arlington evaluation estimated a cost effectiveness of \$31,445/ton of NO_x removed.

The RACT evaluation for the Covanta Fairfax facility addressed the potential for installing SCR at that site. This evaluation also cited the same new MWC facility SCR installation as Babcock Power used in their Wheelabrator Baltimore facility evaluation, along with the 50 ppmvd @7% O₂ 24-hr NO_x rate limit and 45 ppmvd @7% O₂ 30-day NO_x rate limit. The Covanta Alexandria/Arlington evaluation estimated a cost effectiveness of \$15,898/ton of NO_x removed.

For Florida's Palm Beach Renewable Energy Facility, which was a new MWC facility, the use of SCR and a 50 ppmvd @7% O₂ NO_x (24-hr average) emission rate were considered BACT when the facility was permitted in 2010.


Based on these NO_x reduction technology retrofit cost effectiveness estimations for the few existing MWC facilities discussed above, all technologies except SCR could potentially be considered in a revised RACT review for some of the OTR MWC facilities, from a technical standpoint, depending on unit specific design and operating conditions. However, the estimated cost effectiveness of the options may not be considered reasonable for any revised RACT.

The only cost effectiveness information associated with potential NO_x reduction technologies that provides the consistency of same design and same operating characteristics is presented in the Babcock Power NO_x control evaluation for the Wheelabrator Baltimore facility. The evaluation provided estimated costs and NO_x control capability of several NO_x reduction technologies, allowing a reasonable comparison of the impact of the control technologies. The incremental cost effectiveness values in the below chart were estimated from the data provided in the Babcock

Power document, by assuming a 20-year control life with 6% interest rate. For this facility and group of potential NOx reduction technologies, NOx reduction cost effectiveness is optimized when the control technology reduces NOx emissions to approximately 120 ppmvd @7% O₂. Note that the baseline comparison for this estimate is compliance with a 150 ppmvd @7% O₂ 24-hr average NOx emission rate.

Estimated NOx Control Cost Effectiveness

Estimates based on Babcock Power Wheelabrator Baltimore Study



The NOx reduction technologies associated with the controlled NOx rate values in the above chart are in shown in the following table.

Information from Babcock Power Study of Wheelabrator Baltimore

Control Technology	Estimated 24-hr Avg NOx Rate (ppmvd @7%O ₂)
Estimate Base	150
Optimize Existing SNCR	135
FGR & Existing SNCR	120
ASNCR	110
FGR & ASNCR	105
SCR	50

The above information suggests that for this facility with these NOx control technologies, the most cost-effective options are FGR&SNCR and ASNCR. The associated controlled NOx emission rates are between 110 ppmvd @7% O₂ and 120 ppmvd @7% O₂, 24-hr average. The range of NOx control estimated cost effectiveness is \$3,470/ton to \$3,883/ton.

These indications are somewhat in agreement with the RACT analysis conducted by Virginia and Covanta for the Covanta Fairfax and Covanta Alexandria/Arlington facilities. For these Covanta facilities, RACT was selected as Covanta’s proprietary LNTM technology and SNCR with predicted NOx emission rate values of 110 ppmvd @7% O₂, 24-hr average. The analysis indicated a NOx control cost effectiveness of \$2,888/ton for Covanta Fairfax and \$4,005/ton for Covanta Alexandria/Arlington. These values are comparable to the range of controlled NOx rate and cost effectiveness estimated for the Wheelabrator Baltimore facility. While cost effectiveness values would vary across MWCs, the control technologies would likely maintain the same relative cost effectiveness positioning.

While any revised RACT is unit-specific based on technical and economic feasibility of marketed control technologies, the limited information above suggests that a revised NOx RACT rate of between 110 ppmvd @7% O₂ and 120 ppmvd @7% O₂, 24-hr average, may be a reasonably achievable target emission rate for many MWCs. The limited information also suggests that NOx reduction cost effectiveness values of \$3,000/ton to \$4,000/ton may be reasonably representative of the range of related costs to achieve a revised NOx RACT emission rate. Within this cost range, several NOx reduction technologies may be available for consideration to comply with a revised RACT for MWCs.

The following table shows the estimated NOx reductions on a PTE basis for the fleet of OTR MWCs. The estimates assume no backsliding for MWCs that are already subject to NOx rate limitations lower than the assumed NOx RACT rates discussed in this analysis and that all subject units are able to attain the assumed NOx RACT rates. The estimated reductions also assume all the MWCs can technically and economically attain the assumed NOx rate values. As indicated in the table, the estimated NOx PTE reduction for the OTR MWC fleet associated with a NOx rate of 120 ppmvd @7% O₂ is approximately 25%.

Estimated OTR MWC Fleet NOx Emission Reductions Using Assumed NOx RACT Emission Rate Targets

Assumed NOx RACT Value (ppmvd@ 7%O ₂)	Est Hourly PTE (lb)	Est Daily PTE (tons)	% Reduction
Existing Rates	6395.4	76.4	
150	5778.8	69.3	9.3
140	5471.8	65.7	14.0
130	5091.7	61.6	19.4
120	4724.7	56.7	25.8

Appendix G: Method for Estimating Costs for Urea Consumption

The cost estimation for urea consumption for NO_x removal was performed in two ways. First, the cost estimate on a per lb of NO_x reduction was performed using information presented in the Wheelabrator Baltimore study and specifically the differences between the optimized SNCR and advanced SNCR control options. Using this Wheelabrator Baltimore study information, the incremental NO_x reduction cost effectiveness was estimated to be \$0.89 per pound of NO_x reduced. The second estimation method was based on simple chemical reaction estimates, high efficiency NSR guidance from EPA, and urea cost values from the Wheelabrator Baltimore study. Using this second estimation methodology, the cost effectiveness was estimated to be \$1.01 per pound of NO_x reduced. Details of the utilized estimation methodologies are included below.

Using the estimated cost effectiveness values and the mass reduction values shown in the workgroup summary document, the estimated annual O&M cost reductions for the two facilities are shown in the following table:

Facility	Workgroup Paper Identified Change In NO _x Mass Reduction (tons/yr)	Workgroup Paper Existing Estimated O&M Cost (\$/yr)	Estimated O&M Cost Reduction Due To Urea Consumption Based On Wheelabrator Baltimore Study (\$/yr)	Estimated O&M Cost Reduction Due To Urea Consumption Based On Chemistry/EPA NSR (\$/yr)
Alexandria/Arlington	18.33	213773	32627	37027
Fairfax	51.73	493322	92079	104495

As can be seen in the cost per pound of NO_x reduction estimates, there is a \$0.12/lb difference between the two methodologies. One possible explanation is that in reality there is no need to have an NSR as high as 2.0 (as was assumed for the chemistry based estimate) to achieve the target 110 ppmvd @7% O₂ limit when there is improved reagent furnace penetration and mixing with ASNCR. The workgroup has used the Wheelabrator study information for adjusting the estimated O&M costs for the workgroup document.

Incremental Cost Estimation for Urea Consumption Using Wheelabrator Baltimore Study*

From EPA Method 19, eq 19-1: $E = CdFd(20.9/(20.9 - \%O_2))$

where: E = pollutant emission rate lb/MMBTU

Cd = pollutant sample concentration dry basis lb/scf

Fd = fuel specific factor volume of dry combustion products per fuel heat content 9570 dscf/MMBTU for municipal waste

Incremental NOx rate reduction: From 135 ppmvd limit to 110 ppmvd limit = 25 ppmvd Cd NOx = 25 ppmvd x (1.194 x 10⁻⁷ (lb/ft³)/ppm) = 29.9 x 10⁻⁷ lb/ft³

$$E = (29.9 \times 10^{-7} \text{ lb/ft}^3)(9570 \text{ dscf/MMBTU})(20.9/(20.9 - 7)) = 0.0430 \text{ lb/MMBTU}$$

Incremental annual NOx mass reduction: 0.0430 lb/MMBTU x 3 boilers x 325 MMBTU/hr/boiler * 8760 hr/yr * 0.92 availability = 337882 lb/yr 168.9 tons/yr

Annual average change in cost per incremental reduction = (995,000\$/yr – 695,000\$/yr) / (337,882 lb/yr) = 0.8879 \$/lb or 1776.20 \$/ton

*Ref: WASTE TO ENERGY NOX FEASIBILITY STUDY; PREPARED FOR: WHEELABRATOR TECHNOLOGIES BALTIMORE WASTE TO ENERGY FACILITY BALTIMORE, MARYLAND; BPE PROJECT NO. : 100825; BPE DOCUMENT NO.: 100825-0908400100; FINAL REVISION FEBRUARY 20, 2020

*Study operating assumptions: Three Stirling boilers of 750 tpd capacity each (municipal solid waste at 5200 BTU/lb) ~ 325 MMBTU/hr/boiler

92% annual operating factor



Urea mixture cost \$1.19/gal, 50% urea by weight

*Study Control Option – Optimize Existing SNCR - 135 ppmvd 24-hr avg @7% O₂, estimated annual urea consumption cost ~ \$695,000/yr, estimated urea consumption 72 gal/hr

*Study Control Option – Advanced SNCR - 110 ppmvd 24-hr avg @7% O₂, estimated urea consumption cost ~ \$995,000/yr, estimated urea consumption 105 gal/hr

Incremental Cost Estimation Using Basics

Assumption NO_x – 95% NO, 5% NO₂



Est mix MW (95% NO, 5% NO₂) >>> 30.8 lb

Est urea requirement (per lb/mole NO_x) >>>31.54 lb (theoretical NSR)

Theoretical NSR for urea/NO_x = 0.5

Hi-efficiency removal operating NSR for urea/NO_x - 2.0 (ref Fig 1.7, <https://www.epa.gov/sites/production/files/2017-12/documents/snrcostmanualchapter7thedition20162017revisions.pdf>)

Est required urea for high efficiency NSR=2 (per lb/mole of NO_x) >>> 126.16 lb urea / 30.8 lb NO_x = 4.09 lb

Weight of 50% by weight water/urea – 9.57 lb/gal urea = 4.79 lb urea/lb mixture

Urea/water mixture consumption @ 2.0 NSR – 4.09 lb urea / (4.79 lb urea/gal mixture) = 0.85 gal urea/lb NO_x removed

Est water/urea mixture cost range (@ 1.19\$/gal from Wheelabrator Baltimore report, 2020 value) 0.85 gal/lb NO_x x \$1.19/gal = \$1.01/lb NO_x removed